

# BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/building/

# **NOTICE OF ACCEPTANCE (NOA)**

Gardner Asphalt Corporation 4161 E. 7 Avenue Tampa, FL 33605

#### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed by Miami-Dade County Product Control Section and accepted by the Board of Rules and Appeals (BORA) to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BORA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### **DESCRIPTION:** APOC/Gardner Asphalt Cements, Adhesives and Coatings

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

MATERIA

This renews and revises NOA# 09-0908.05 and consists of pages 1 through 15. The submitted documentation was reviewed by Alex Tigera.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 1 of 15

# **ROOFING COMPONENT APPROVAL**

Category:

Roofing

Sub-Category:

Cement-Adhesive-Coatings

Material:

Asphalt

Maximum Design Pressure

N/A

## **APPROVED DISTRIBUTORS:**

Gardner Asphalt Corporation products are also distributed by RSI, Tri-Built Materials Group and Roof Doctor Inc.

## **EVIDENCE SUMITTED:**

Test Agency	Test Identifier	Test Name/Report	<u>Date</u>
<del></del>	R13663	Fire Classification	1994
Underwriter Laboratories, Inc.	R13003 R11333	Fire Classification	1994 1999
	R11333 R13663		2005
	R13663		2003
	K13003		2008
PRI Asphalt Technologies	GGI-025-02-01	Physical Properties	01/12/06
-	GGI-020-02-01	ASTM Compliance	01/03/06
	GGI-022-02-01	•	01/11/06
	GGI-021-02-01		01/03/06
	GGI-027-02-01		01/03/06
	GGI-019-02-01		01/03/06
	GGI-005-02-01		10/19/05
	GGI-006-02-01		10/19/05
	GGI-017-02-01		10/14/05
	GGI-011-02-01	·	11/16/05
	GGI-024-02-01		01/12/06
	GGI-023-02-01		01/15/06
	GGI-018-02-01		12/21/05
	GGI-004-02-01		10/19/05
	GGI-006-02-01		10/19/05
	GGI-007-02-01		10/19/05
	GGI-046-02-01		02/26/08
	GGI-014-02-01		11/16/05
	GGI-013-02-01		12/16/05
	GGI-029-02-01		01/11/06
	GGI-008-02-02		10/18/05
	GGI-030-02-01		06/19/06
	GGI-016-02-01	•	01/04/06
	GGI-034-02-01		10/27/06
	GGI-083-02-01		01/26/11
	GGI-015-02-01		05/09/06
	GGI-081-02-01		12/13/10
Momentum Technologies, Inc.	DX17L4A		03/15/05



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11 Page 2 of 15

### PHYSICAL PROPERTIES OF COMPONENTS:

Trade names: Gardner Fibered Emulsion Roof Coating #GA 040

APOC #302 Fibered Emulsion Roof Coating #AP 302

APOC #337 Fibered Elastomeric Asphalt Emulsion #AP337 WeatherSeal Fibered Emulsion Roof Coating #WS 240

Black Jack Rubr-Coat #57

**Gardner Flexx-Gard Ruberized Roof Cement** 

APOC #339 RX #300

Thickness:

See Systems Approvals Below.

Specifications:

ASTM D 1227 Type IV

Description:

An asphalt base clay-type emulsion coating containing mineral fibers. Non-flammable and specifically formulated to bond to damp or dry surfaces. For use as a protective surface coating over built-up ply sheets, mineral surfaced cap sheets, approved single ply membranes and other asphalt roof surfaces. Apply one or more coats as required at approximately 1 to 3 gal/100 sq. ft.. Apply second coat at right

angle to first coat.

Container Size:

1, 5, 55 gallons. Note all precautions on container...

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Tradename:

**MBA** Modified Bitumen Adhesive

APOC #136 MBA Modified Bitumen Adhesive #AP 136

PC 607

APOC ArmorFlex # AP525

RX #200

Tri Built Mod Bit Adhesive

Thickness:

See System Approvals Below.

Specifications:

ASTM D 3019, type III

Description:

An asbestos free, polymer modified, asphalt based, cold applied adhesive. For use with modified bitumen membranes, base and ply sheets. Also bonds gravel or granules to BUR roof systems and modified cap sheets. Applied with a notched squeegee, brush or roller forming a continuous film. Applied at the lap so that a continuous bead can be seen at the lap edges. Apply at an approximate rate of 1 to 5gal./100 sq. ft. depending on substrate, slope or application..

Container Size:

1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 3 of 15

Gardner Fibered Roof Coating #GA 010, GA610

APOC #202 Fibered Roof Coating #AP 202 WeatherSeal Fibered Roof Coating #WS 210

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4479 type I

Description:

A heavy duty fibrated coating of brush consistency. For use on metal, composition and built-up roofs. Apply with a brush to form a thin and

continuous film. Apply at an approximate rate of 2 to 3 gal/100 sq. ft

Container Size:

1 quart, 1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Non-Fibered Roof Coating #GA 011, GA 012 APOC #200 Non-Fibered Roof Coating #AP 200

WeatherSeal Non-Fibered Roof Coating #WS211, WS 212

Thickness:

See System Approvals Below.

Specifications:

**ASTM D 3019** 

Description:

A solvent and asphalt based, non-fibered coating. For use over concrete or masonry surfaces, asphalt composition roofing, built-up roofing or as an anticorrosive coating on metal. It may be used as an asphalt primer. Apply with brush or spray to form a thin and continuous film. Apply at an approximate rate of 1 to 3-gal/100 sq. ft., depending upon surface texture and job requirements.

Container Size:

1, 5, 55 gallons. Note all precautions on container.

System Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Gardner Lap Cement # GA 035

PC 601

Thickness:

See System Approvals Below

Specifications:

ASTM D 3019 Type III

Description:

An asphalt based general purpose lap and ply cement for cold process roofing. For use for bonding laps of asphalt roll roofing to each other, masonry or other

surfaces.

Container Size:

1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

MIAMI-DADE COUNTY
APPROYED

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 4 of 15

Gardner Cold Process Roof Cement # GA 036, GA 636

APOC #107 Fibrex Cold Process Adhesive #AP 107

APOC #107 Cold Process Adhesive #AP 107

APOC #108 Cold Process & Lap Adhesive #AP 108 WeatherSeal Cold Process Roof Cement #GA 236

Thickness:

See System Approvals Below.

Specifications:

ASTM D 3019 Type III

Description:

A fibered, asphaltic, quick drying, cold applied adhesive. For use in new construction and reroofing to bond plies of build-up roofing materials. Also bonds gravel or granules to BUR roof systems and modified cap sheets. Apply with a brush, notched squeegee, or trowel to form a thin and continuous film. Apply at an approximate rate of 1 1/2 to 5 ga1/100 sq.ft. depending upon surface

texture and job requirements.

Container Size:

1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Gardner Wet Surface Roof Cement #GA 037, GA 637 APOC #109 Wet Surface Plastic Roof Cement #AP 109 APOC #124 Wet Surface Roof Cement #AP124 WeatherSeal Wet Surface Roof Cement #WS 237

PC 105

Tri Built Wet/Dry Plastic Cement

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4586 Type I and ASTM D 3409

Description:

An all weather asphalt plastic cement specially designed to bond to water covered or damp surfaces, as well as dry surfaces. For use to patch splits and cracks less than 1/4" wide in build-up, mineral surfaced cap sheet and smooth surface asphalt roofs. Also used for repair flashings around chimneys, stand pipes and other roof projects. Applied with trowel or putty knife, working material to an even consistency over and into the area to be repaired, approximately 1/8" to 1/4" thick, two or three inches beyond the problem area.

Coverage is approximately 12 1/2" sq. ft. when applied 1/8" thick.

Container Size:

10½, 30 oz. tube, 1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 5 of 15

Gardner Flashing Cement #GA 033 WeatherSeal Flashing Cement #WS 233 Pro's Choice Roofing and Flashing Cement

PC 104

**APOC LV Cement** 

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4586 type I

Description:

A fibered asphalt based roof cement. Used to set and repair flashings, gutters, sills, lintels, copings, skylights, all types of roofing and siding. Also used as a water-resistant material for coating exterior walls above or below grade. Apply with trowel or putty knife, working material to an even consistency over and into the area to be repaired, approximately 1/8" to 1/4" thick, two or three inches beyond the problem area. Coverage is approximately 12 1/2 sq. ft. when applied 1/8" thick.

Container Size:

10½, 30 oz. tube, 1, 5, 55 gallons. Note precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Tradename:

Gardner Aluminum Fibered Roof Coating Professional Grade #GA 722 and

**GA 621** 

APOC # 208 Fibered Aluminum Roof Coating #AP 208

WeatherSeal Fibered Aluminum Roof Coating #WS 221, WS 222

PC #401 Fibered Aluminum Roof Coating

**Tri Built Fiber Aluminum Coating** 

Thickness:

See System Approvals Below.

Specifications:

ASTM D 2824 Type III

Description:

A fibered aluminum roof coating used to protect underlying roofing materials and to reflect the sun's rays. Applied by spray or brush at an approximate rate of

1 gal/50 to 100 sq. ft...

Container Size:

1, 5, 55 gallons. Note all precautions on container.

System Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 6 of 15

Gardner Aluminum Fibered Roof Coating #GA 723

APOC #212 Fibered Aluminum Roof Coating #AP 212 APOC #214 Fibered Aluminum Roof Coating #AP 214

RX #450

Thickness:

See System Approvals Below.

Specifications:

ASTM D 2824 Type III and ASTM D 3805

Description:

A reflective, aluminum roof coating with fibers which strengthen the protective film. Recommended for emulsion surfaced or mineral surfaced roofs. Apply evenly by spray or soft brush and avoid scraping into soft roof surfaces. Apply at

an approximate rate of 1 gal/50 to 100 sq. ft..

Container Size:

1, 5, 50 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Gardner Non-Fibered Emulsion Roof and Foundation Coating #GA 042

APOC #300 Non-Fibered Emulsion #AP 300

WeatherSeal Non-Fibered Emulsion Roof & Foundation Coating #WS 242

Thickness:

See System Approvals Below.

Specifications:

ASTM D 1227 Type III

Description:

An asphalt based emulsion coating for resurfacing and coating flat deck roofing. Specially formulated for bonding to damp or dry surfaces. For use over built-up ply sheets, mineral surfaced cap sheets and other asphalt roof surfaces. Also for use as below grade damproofing. Apply with a brush or suitable spray equipment in one or more coats as required. Apply at an approximate rate of 1 gal/50 sq.ft..

Container Size:

1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11 Page 7 of 15

Gardner Non-Fibered Aluminum Roof Paint #GA 726

APOC #211 Aluminum Roof Paint #AP 211 APOC #207 Aluminum Roof Paint #AP 207 PC #400 Non-fibered Aluminum Roof Coating

**RX #460** 

Tri Built Non-Fibered Aluminum Coating

Thickness:

See System Approvals Below.

Specifications:

ASTM D 2824 Type 1

Description:

A highly reflective, non-fibered aluminum roof paint. Specially designed to repel the sun's heat on smooth surfaced, emulsion surfaced or mineral surfaced roofs and sheet metal buildings and roofs. Apply by spray, roller or soft brush, spreading in both horizontal and vertical directions. Application rate varies

depending upon surface. See manufacturer's specifications.

Container Size:

1, 5, 50 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Gardner Professional Asphalt Primer #GA 014, GA 714

APOC #103 Asphalt Primer #AP 103 WeatherSeal Asphalt Primer #WS 214

PC #200 Asphalt Primer

Tri Built Quick Dry Asphalt Primer

Thickness:

See System Approvals Below.

Specifications:

ASTM D 41

Description:

Asphalt primer used to seal newly laid concrete or cement decks prior to applying build-up roofing. Also for use with below grade damproofing and waterproofing and as a primer on existing roofs prior to recoating or restoration. Apply with brush or spray, working the material to a smooth and even consistency. Apply at an approximate rate of 1 gal/150 to 200 sq. ft.

Note: Do not thin. Do not apply to wet or damp surfaces.

Container Size:

1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 8 of 15

Trade Name: Gardner Plastic Roof Cement #GA 634, GA 034, GA 734

APOC #100 Plastic Roof Cement #AP 100

APOC #104 Rain Proof Plastic Roof Cement #AP 104

APOC #101 Plastic Roof Cement #AP 101 WeatherSeal Plastic Roof Cement #WS 234

PC #103

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4586 Type 1

Description:

All purpose, black plastic cement for all types of roof repairs and foundation applications. Apply with trowel or putty knife, working material to an even consistency over and into the area to be repaired, approximately 1/8" to 1/4" thick, two or three inches beyond the problem area. Note: Do not thin. Do not use on wet or damp surfaces.

Container Size:

10½, 30 oz. tube, 1, 5, 55 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

Gardner Asbestos Free Flashing Cement #GA 633, GA 033, GA 132

APOC #122 Flashing Cement #AP 122 APOC #128 Flashing Cement #AP128

PC #104 Flashing Cement Tri Built Flashing Cement

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4586 Type 1 and ASTM D 3409

Description:

Asbestos free, asphalt based trowelable flashing cement for roof and foundation applications.. Apply with a putty knife or trowel, filling all fissures, joints and gaps. Apply at an approximate rate of 1/8" thick; 1 gal/12 1/2 sq. ft.. When used on a bonded or warranted roof system, follow instructions of that application

system.

Container size:

10½, 30 oz. tube, or 1, 3, 5 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 9 of 15

APOC #133 Rubberized Flashing Cement APOC #365 Rubberized Flashing Cement

APOC #115 Black Gold Rubberized Flashing Cement

PC #801 Rubberized Flashing Cement

**RX #100** 

Tri Built SBS Premium Roof Cement Tri Built Ultimate Rubberized Cement

Thickness:

See System Approvals Below.

Specifications:

ASTM D 4586 Type I and ASTM D 3409

Description:

Asbestos free, asphalt based trowelable rubberized flashing cement for all types of roof and foundation applications. Apply with a putty knife or trowel, filling all fissures, joints and gaps. Apply at an approximate rate of 1/8" thick; 1 gal/12 1/2 sq. ft. When used on a bonded or warranted roof system, follow instructions of

that application system.

Container size:

10-1/2" oz. tube and 1, 3, 5 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Names:

APOC #400 Sunbrite AP#400 Gardner Silver Shield #6290-GA

#5180-A (Black Jack)

Thickness:

See System Approvals Below.

Specifications:

TAS 138-95

Description:

A highly reflective, water based, aluminum emulsion roof coating for use over BUR roofs, Cap Sheets, Modified Bituminous Membranes and Metal Roofs.

Container Size:

5, 55, 275 gallons

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Names:

APOC #501 Superflash Neoprene AP# 501

Black Jack 1010

Thickness:

See System Approvals Below.

Specifications:

**ASTM D 4586** 

Description:

A solvent based neoprene flashing cement to be used as a topical repair mastic over concrete, aged asphalt, wood, metal, polyurethane foam, pitch pockets and

granule surfaced cap sheets.

Container Size:

tube, 1, 3, gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

MIAMI-DADE COUNTY
APPROVED

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 10 of 15

APOC #502 Brushable Neoprene AP #502

Thickness:

See System Approvals Below.

Specifications:

**ASTM D 4479** 

Description:

A brushable, solvent based Neoprene sealant and coating to be used as a topical repair mastic over concrete, aged asphalt, wood, metal, polyurethane foam, pitch

pockets and granule surfaced cap sheets.

Container Size:

1, 3 gallons. Note all precautions on container.

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Names:

Leak Stopper

**GA 031** 

Thickness:

See System Approvals Below.

Specifications:

**ASTM D 4586** 

Description:

A solvent based, rubberized roof patch. A polyester reinforcing fabric is

recommended when sealing cracks.

Container Size:

tube, 1, 3 gallons, 55 gallon drum

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Names:

APOC #260 AMAZ'N STUFF Roof Patch AP #260

**APOC #264** 

APOC #505 Patch N Seal

**RX 905** 

Thickness:

See System Approvals Below.

Specifications:

TAS 139-95

Description:

An elastomeric roof patch applied to seal cracks on metal roofs, cement tiles,

wood, structural concrete roofs, aged smooth asphalt roofs, aged granule

surfaced cap sheets, polyurethane foam roofs, and aged roofs previously coated

with asphalt and approved single ply membranes.

Container Size:

1, 3, 5, gallons

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 11 of 15

APOC #252 FR

**APOC # 252 Sunwhite AP #252** 

APOC #258 AP# 258

APOC #258 EPDM Renew It APOC #247 Sun Shield, AP #247 APOC # 248 Arizona White, AP #248

RX #700 RX #500

**Black Jack Ultra-Roof Elastomeric** 

Sta-Kool 780

Thickness:

Apply a Base Coat at a minimum rate of 1 ½ gal per square and a finish coat at 1

½ gal per square.

Specifications:

**ASTM D 6083** 

Description:

A reflective elastomeric coating membrane applied to, BUR membranes, Metal Roofs, EPDM membranes, Cement Tiles\* (Flat or Barrel), Bonded Gravel Roofs, Polyurethane Foam Roofs, pitch pockets, granule surface cap sheets and Aged Roofs previously coated with asphalt.

Container Size:

1, 5, 55 and 275 gallons

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

\*Tile system shall be in accordance with tile roof manufacturer's NOA and RAS 118, 119 or 120. The coating membrane shall be applied such that the tile headlaps are not filled or 'clogged' with coating material, so as to maintain an air-

permeable tile roof system

Trade Names:

APOC #256

Maxx-Cool

Thickness:

Apply a Base Coat at a minimum rate of 1 ½ gal per square and a finish coat at 1

½ gal per square.

Specifications:

**ASTM D 6083** 

Description:

A reflective elastomeric coating membrane applied to galvanized steel.

Container Size:

1, 5, 55 and 275 gallons

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

Trade Name:

APOC #545 AP#545

RX #900

Thickness:

See System Approvals Below.

Specifications:

**ASTM D 6083** 

Description:

A solvent based, SEBS coating for use over galvanized metal with 250 primer.

Container Size:

1, 5, 55 gallons

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance.

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 12 of 15



APOC #560 Primer

Thickness:

Apply at a minimum of 1 gal per square.

Specifications:

ASTM D903

Description:

A water based primer used with s/a ply, base or underlayment.

Container Size:

5 gallon can

Systems Approvals:

Methods of application and quantities shall comply with the specific Roof

Assembly, Product Control Notice of Acceptance



NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 13 of 15

#### APPROVED EXISTING SUBSTRATES:

#### SYSTEM 1

Substrate: **Existing Metal Roof Panel System** 

Preparation: Power wash the metal panel surface. Rusted areas should be wire brushed to

remove all surface rust. Follow all published Gardner / APOC application

instructions.

Flashing: Treat all exposed fasteners with APOC #260 mastic or APOC #501 neoprene

cement. Vertical and horizontal lap seams, curbs, vents and edge trim must be

sealed with a three course of APOC #260 and APOC #483 polyester

reinforcement or APOC #502 brush grade neoprene and APOC #483 polyester

reinforcement.

Base Coat: APOC #252 grey elastomeric coating shall be applied at the rate of 1.5 gallons

per square.

Finish Coat: After the base coat has dried to the touch, apply APOC #252 at the rate of 1.5

gallons per square.

**SYSTEM 2** 

Substrate: Existing BUR, Modified SBS cap or Modified APP cap system

Preparation: Remove all loose gravel and/or surface dust using power wash, blower or

> vaccum. Let dry. Prime surface at the rate of ½ to 1 gallon per square using APOC #103 asphalt primer. Follow all published Gardner / APOC application

instructions.

Flashing: Repair all splits, reinforce perimeters, curbs and penetrations using a three

course of either APOC #365, APOC #133, APOC #501 or APOC #502 and

APOC #483 polyester reinforcement.

Surfacing: Squeegee APOC #525 ArmorFlex at the rate of 3 to 5 gallons per square and

apply an even coat of ceramic granules.

SYSTEM 3

Substrate: Existing BUR, Modified SBS cap, Modified APP cap system, Gravel, Single Ply

or Metal panel system.

Preparation: Remove gravel as specified. Power wash as specifications require, Follow all

Gardner / APOC published application instructions.

Flashing: Repair all splits, reinforce perimeters, curbs and penetrations using a three

course of APOC #365, APOC #133, APOC #501 or APOC #502 and APOC

#483 polyester reinforcement.

**Emulsion Coat:** APOC #300 asphalt emulsion shall be spray applied at the rate of 9 gallons per

square with an application of 3 lbs per square of chopped fiber glass roving

blown into the APOC #300 asphalt emulsion. Let cure.

Finish Coat: After the base coat has dried to the touch, apply APOC #400, APOC #212 or

> APOC #211 aluminum roof coating at the rate of 1.5 gallons per square. APOC #252, 248 or 258 may be applied in lieu of Aluminum at a rate of 1.5 gallons per

square per coat for a total rate of 3 gallons per square.

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

MIAMI-DADE COUNTY
APPROVED Page 14 of 15

#### SYSTEM 4

Substrate: Existing BUR, Modified SBS cap or Modified APP cap system

Preparation: Spud and remove all loose and embedded gravel on BUR systems. Power wash

granular cap sheets and smooth BUR systems. Follow all published Gardner /

APOC application instructions.

Flashing: Repair all splits, reinforce perimeters, curbs and penetrations using a three

course of APOC #365, APOC #133, APOC #501, or APOC #502 and APOC

#483 polyester reinforcement.

Emulsion Coat: Apply APOC #300 asphalt emulsion at the rate of 4 gallons per square. Embed

one ply of APOC #483 polyester reinforcement and broom into emulsion.

Base Coat: Apply one coat of APOC #252 grey elastomeric coating at the rate of 1.5 gallons

per square.

Finish Coat: Apply one coat of APOC #252 white elastomeric coating at the rate of 1.5

gallons per square.

### **LIMITATIONS:**

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.

2. Gardner Asphalt products shall not be applied in inclement weather conditions.

The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.

- 4. All products listed herein shall have an unannounce follow-up quality control program from an approved listing agency. Follow up test results shall be made available to BCCO upon request.
- 5. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
- 6. Gardner Asphalt Corporation products shall be applied in accordance with manufacturer's published application instructions.
- 7. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



# END OF THIS ACCEPTANCE

NOA No.: 10-0323.03 Expiration Date: 02/01/16 Approval Date: 02/24/11

Page 15 of 15

