

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786)315-2590 F (786) 31525-99

www.miamidade.gov/pera

DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY AFFAIRS (PERA) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA) Gaco Western LLC

1245 Chapman drive Waukesha, WI 53186

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: : GACO WESTERN ROOF COATING SYSTEMS

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 09-1109.03 and consists of pages 1 through 4. The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 12-0426.06 **Expiration Date: 05/31/17** Approval Date: 05/24/12

Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing

Sub-Category: Cement-Adhesive-Coatings

Elastomeric Material:

SCOPE:

This approves GACO WESTERN ROOF COATING SYSTEMS" as a roof maintenance coatings manufactured by Gaco Western LLC, as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	Date
PRI Construction Materials	GWI-007-02-01	ASTM D 6083	08/14/09
Technologies		Fed Spec TT-C-555B	
	GWI-002-02-201	ASTM D 6083	01/09/07
		Fed Spec TT-C-555B	
	GWI-001-02-01	ASTM D 6694	04/10/07
		Fed Spec TT-C-555B	
	GWI-004-02-01	ASTM D 6694	05/13/08
		Fed Spec TT-C-555B	
Underwriters Laboratories	Project 04NK27341	UL 790	02/01/05
	Project 07NK02171	UL 790	03/13/07
	Project 08NB01503	UL 790	02/21/08
Factory Mutual Research Corp.	3023644	4470	02/02/07

MANUFACTURING LOCATION:

1. Waukesha, WI

PHYSICAL PROPERTIES OF COMPONENTS

Trade names: A3100R Acrylic Top Coat

Thickness: For application over spray polyurethane foam system apply a base coat at a

minimum rate of 1.13 gal/100 ft², an intermediate coat at a minimum rate of 1.13

gal/100 ft², and a top coat at a minimum rate of 1.13 gal/100 ft².

For application of a recover coating over an existing acrylic roof apply a base coat at a minimum rate of 1 gal/100 ft², and a top coat at a minimum rate of

1 gal/100 ft².

ASTM D 6083 Specifications:

Description: An acrylic white elastomeric quick set coating membrane applied to; spray

polyurethane foam roof systems and a recover of any existing acrylic roof.

Container Size: 5, 55 gallons. Note all precautions on container.

Methods of application and quantities shall comply with specific Roof **Systems Approvals:**

Assembly, Product Control Notice of Acceptance.



NOA No.: 12-0426.06 **Expiration Date: 05/31/17** Approval Date: 05/24/12 Page 2 of 4

Trade names: S 1000 Top Coat

Thickness: For application over spray polyurethane foam system apply a base coat at a

minimum rate of 1.1 gal/100 ft and a top coat at a minimum rate of 1.1 gal/100

ft².

For application of a recover coating over an existing silicone roof apply a base coat at a minimum rate of 1.1 gal/100 ft², and a top coat at a minimum rate of

1.1 gal/100 ft².

Specifications: ASTM D 6694

Description: A single component, air dried, silicone-based rubber elastomeric membrane

coating that is brush, roller or spray-applied. To be applied to spray polyurethane

foam roof systems and as a recover of any existing silicone roof coatings.

Container Size: 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof

Assembly, Product Control Notice of Acceptance.

Trade names: S-2000 Solventless Silicone Basecoat/Top Coat

Thickness: For all applications apply 2 coats; a base coat at a minimum rate of .75 gal/100 ft

and a top coat at a minimum rate of .75 gal/100 ft².

• Spray Polyurethane Foam Roof Systems

• Acrylic Coatings

• Galvanized Metal Roofs (in conjunction with E5320 2 part Epoxy Primer)

• Smooth Built Up Roof Systems (in conjunction with E5320 2 part Epoxy Primer)

• EPDM Single Ply Roof Systems (in conjunction with E5320 2 part Epoxy Primer)

• PVC Single Ply Roof Systems (in conjunction with E5320 2 part Epoxy Primer)

Specifications: ASTM D 6694

Description: A single component, moisture cured, silicone-based rubber elastomeric

membrane coating that is brush, roller or spray-applied to the roof covers listed

above.

Container Size: 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof

Assembly, Product Control Notice of Acceptance.



NOA No.: 12-0426.06 Expiration Date: 05/31/17 Approval Date: 05/24/12 Page 3 of 4 Trade names: S 1600 Base Coat/Top Coat

Thickness: For application over spray polyurethane foam system apply a base coat at a

minimum rate of 1.1 gal/100 ft and a top coat at a minimum rate of 1 gal/100 ft².

For application of a recover coating over an existing silicone roof apply a base coat at a minimum rate of 1 gal/100 ft², and a top coat at a minimum rate of

1 gal/100 ft².

Specifications: ASTM D 6694

Description: A single component, moisture cured, silicone-based rubber elastomeric

membrane coating that is brush, roller or spray-applied. To be applied to spray polyurethane foam roof systems, galvanized metal, smooth surfaced built-up (BUR) roofing, acrylic coating and any existing silicone roof coating..

Container Size: 1, 5 and 55 gallons. Note all precautions on container.

Systems Approvals: Methods of application and quantities shall comply with specific Roof

Assembly, Product Control Notice of Acceptance.

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.

- 2. GACO WESTERN ROOF COATING SYSTEM shall not be applied in inclement weather conditions.
- 3. GACO WESTERN ROOF COATING SYSTEM shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
- 4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. For applications over existing single ply, smooth or granulated BUR systems. Refer applicable building code for requirements.
- 5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
- 6. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



- 7. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
- 8. GACO WESTERN ROOF COATING SYSTEM shall only be applied by a factory trained and certified applicators.
- 9. GACO WESTERN ROOF COATING SYSTEM shall be applied in accordance with manufacturer's published application instructions.

END OF THIS ACCEPTANCE

NOA No.: 12-0426.06 Expiration Date: 05/31/17 Approval Date: 05/24/12 Page 4 of 4

