



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

RoofMart International, Inc.  
P.O. Box 502  
Chapman, KS 67431

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: RMI- FLUID APPLIED MEMBRANE COATING SYSTEMS**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 06-0912.08 and consists of pages 1 through 5.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 13-0730.03  
Expiration Date: 09/11/18  
Approval Date: 08/29/13  
Page 1 of 5

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cement-Adhesive-Coatings  
**Materials:** Elastomeric

### SCOPE:

This approves “**RMI- FLUID APPLIED MEMBRANE COATING SYSTEMS**” for use as roof maintenance coatings, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

### MANUFACTURING LOCATIONS:

1. Chapman, KS

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Momentum Technologies, Inc.	EX17A5D1	ASTM D 6083	07/17/08
	RX25G7A	ASTM D 6083	06/18/08

### PHYSICAL PROPERTIES OF COMPONENTS

Trade name: **Garna-White Top Coat**

Application Rate: 1 to 2 gallon per 100 ft.<sup>2</sup> to an average of 13 - 26 dry mils

Specifications: ASTM D 6083

Description: A bright white, moisture cured, single component, aliphatic urethane top coat membrane applied to; EPDM, Steel, SBS smooth surfaced and Garna-Flex Base Coat.

Container Size: 5, 55 gallons containers; Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly, Product Control Approval.

  

Trade name: **Garna-Flex Basecoat**

Application Rate: 2 to 3 gallon per 100 ft.<sup>2</sup> to an average of 32 - 48 dry mils

Specifications: ASTM D 6083

Description: A plural component, 100% solids, PolyGlycol based rubber like elastomeric membrane basecoat that is applied to; EPDM, Steel, Granule surfaced SBS cap membranes and Smooth surfaced SBS cap membranes (in conjunction with Garna-Prime Urethane Primer Adhesive). In all cases Garna-Flex Basecoat shall be used with a topcoat of Garna-White Top Coat.

Container Size: 1, 5, 55 gallons containers; Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly, Product Control Approval.



Trade name: **Garna-Prime Primer**

Application Rate: .25 to .5 gallon per 100 ft.<sup>2</sup> to an average of 4 to 8 dry mils

Specifications: Proprietary

Description: A fluid applied, single component, aromatic primer that gives better adhesion for foundation coating products.

Container Size: 5, 55 gallons containers; Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly, Product Control Approval.

### **APPROVED EXISTING SUBSTRATES:**

**Substrate: Existing Steel Metal Roof Panel System**

#### **Preparation:**

The existing surface should be smooth, clean and dry prior to the application of the Garna-Prime Urethane Primer Adhesive Coating at a minimum application rate of 1 gallon per 4 squares to an average of 4 dry mils. All surface preparation shall be in compliance with RoofMart International's current published application instructions.

#### **Foundation Coat**

Apply Garna-Flex Base Coating at a minimum application rate of 3 gallon per square in one coat to an average of 48 dry mils thick. Allow to thoroughly dry before application of the finish coat. All applications shall be in compliance with RoofMart International's current published application instructions.

#### **Finish coat:**

Apply Garna-White Top Coat Roof Coating at a minimum application rate of 1.5 to 2 gallons per square in one coat to an average of 19 to 26 dry mils thick.

**Substrate: Existing EPDM Single Ply Roof System**

#### **Preparation:**

The existing surface should be smooth, clean and dry prior to the application of the Garna-Prime Urethane Primer Adhesive Coating at a minimum application rate of 1 gallon per 4 squares to an average of 4 dry mils. All surface preparation shall be in compliance with RoofMart International's current published application instructions.

#### **Foundation Coat**

Apply Garna-Flex Base Coating at a minimum application rate of 2 gallons per square in one coat to an average of 32 dry mils thick. Allow to thoroughly dry before application of the finish coat.

#### **Finish coat:**

Apply Garna-White Top Coat Roof Coating at a minimum application rate of 1.5 to 2 gallons per square in one coat to an average of 19 to 26 dry mils thick.



**Substrate: Existing Granular Surfaced SBS Roof System**

**Preparation:**

The existing surface should be smooth, clean and dry prior to the application of the Garna-Prime Urethane Primer Adhesive Coating at a minimum application rate of 1 gallon per 4 squares to an average of 4 dry mils. All surface preparation shall be in compliance with RoofMart International's current published application instructions.

**Foundation Coat**

Apply Garna-Flex Base Coating at a minimum application rate of 2 gallons per square in one coat to an average of 32 dry mils thick. Allow to thoroughly dry before application of the finish coat.

**Finish coat:**

Apply Garna-White Top Coat Roof Coating at a minimum application rate of 1.5 to 2 gallons per square in one coat to an average of 19 to 26 dry mils thick.

**Substrate: Existing Smooth Surfaced SBS Roof System**

**Preparation:**

The existing surface should be smooth, clean and dry prior to the application of the Garna-Prime Urethane Primer Adhesive Coating at a minimum application rate of 1 gallon per 4 squares to an average of 4 dry mils. All surface preparation shall be in compliance with RoofMart International's current published application instructions.

**Foundation Coat**

Apply Garna-Flex Base Coating at a minimum application rate of 2 gallons per square in one coat to an average of 32 dry mils thick. Allow to thoroughly dry before application of the finish coat.

**Finish coat:**

Apply Garna-White Top Coat Roof Coating at a minimum application rate of 1.5 to 2 gallons per square in one coat to an average of 19 to 26 dry mils thick.



**LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. RMI- FLUID APPLIED MEMBRANE COATING SYSTEMS shall not be applied in inclement weather conditions.
3. RMI- FLUID APPLIED MEMBRANE COATING SYSTEMS shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance. Refer applicable building code for requirements.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami Dade Product Control upon request.
6. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



7. RMI- FLUID APPLIED MEMBRANE COATING SYSTEMS shall only be applied by a factory trained and certified applicators and in accordance with manufacturer’s published application instructions.
8. Change in materials use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code

**END OF THIS ACCEPTANCE**

