



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/](http://www.miamidade.gov/)

**NOTICE OF ACCEPTANCE (NOA)**

**Carlisle Syntec, a division of Carlisle Construction Materials Incorporated**  
1285 Ritner Highway  
Carlisle, PA 17013

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Carlisle Sure-Flex Single Ply PVC Roof Systems over Wood Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 16-0404.11 and consists of pages 1 through 7.  
The submitted documentation was reviewed by Alex Tigera.



NOA No: 17-0706.09  
Expiration Date: 08/24/21  
Approval Date: 12/20/18  
Page 1 of 7

**ROOFING SYSTEM APPROVAL**

**Category:** Roofing  
**Sub-Category:** Single Ply  
**Material:** PVC  
**Deck Type:** Wood  
**Maximum Design Pressure** -60 psf  
**Fire Classification:** See General Limitation #1

**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

**TABLE 1**

<u>Product Name</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Sure-Flex	various	TAS131	Reinforced white or colored PVC membrane.
Low VOC PVC Bonding Adhesive	5 gal. pail	TAS 110	Solvent-based bonding adhesive.

**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Polyisocyanurate HP-H	Polyisocyanurate roof insulation.	Carlisle Syntec, Inc.
InsulBase	Polyisocyanurate roof insulation.	Carlisle Syntec, Inc.
DensDeck, DensDeck Prime	Silicon treated gypsum	Georgia-Pacific Gypsum, LLC.
Insulfoam SP	Expanded Polystyrene	Insulfoam
R-Tech, R-Tech Fan-Fold	Expanded Polystyrene	Insulfoam
SECUROCK Gypsum-Fiber Roof Board	Gypsum based board stock	United States Gypsum Corporation



**APPROVED FASTENERS:**

**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	HP, HP-X, HP-Xtra	Insulation and membrane fastener	Various	Carlisle SynTec
2.	Piranha Plates, Piranha Xtra Plates	Metal stress plates.	2-3/8" diameter	Carlisle SynTec
3.	Insulation Fastening Plate	Insulation Plate	3" Diameter	Altenloh, Brinck & Co. U.S., Inc.
4.	Trufast #15 EHD Fastener	Carbon steel screw with #3 phillips drive	#15 x 24" max. length	Altenloh, Brinck & Co. U.S., Inc.
5.	Trufast 2.4" Barbed Metal Seam Plate (14 Barb)	Galvalume steel stress plate	2.4" Round w/ reinforcing ribs	Altenloh, Brinck & Co. U.S., Inc.
6.	Trufast #12 DP Fastener	Carbon steel screw with #3 phillips drive	#12 x 8" max. length	Altenloh, Brinck & Co. U.S., Inc.
7.	Trufast 3" Metal Insulation Plate	Galvalume steel stress plate	3" Round w/ reinforcing ribs	Altenloh, Brinck & Co. U.S., Inc.
8.	Trufast #14 HD Fastener	Carbon steel screw with #3 phillips drive	#14 x 12" max. length	Altenloh, Brinck & Co. U.S., Inc.
9.	Trufast 2" Metal Seam Plate	Galvalume steel stress plate	2" Round with reinforcing ribs	Altenloh, Brinck & Co. U.S., Inc.

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	3021764	4470	01/11/06
	3035880	4470	07/02/09
Atlantic & Caribbean Roof Consulting, LLC	ACRC 07-052	TAS 114 Appendix J	08/30/07
Trinity ERD	C14040.03.12-R1	ASTM D 2196-99	03/28/12



## APPROVED ASSEMBLIES

<b>Membrane Type:</b>	Single Ply, Thermoplastic, PVC, Reinforced
<b>Deck Type 1I:</b>	Wood, Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank
<b>System Type C(1):</b>	All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
One of the following covered with the boards listed in Top Layer.		
DensDeck, DensDeck Prime, Securock Minimum <sup>1</sup> / <sub>4</sub> " thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Polyisocyanurate HP-H or InsulBase Minimum 1.5" thick	1, 2	1:2 ft <sup>2</sup>

Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<b>Vapor Retarder:</b>	(Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.
<b>Membrane:</b>	Sure-Flex, Reinforced, 50, 60 or 80 mil membrane fully adhered to the insulation using Low VOC PVC Bonding Adhesive applied to the substrate at a rate of 1 gal/60 ft. <sup>2</sup> The outside 1.5" of the roof cover lap is heat welded.
<b>Maximum Design Pressure:</b>	-45 psf (See General Limitation #7)



**Membrane Type:** Single Ply, Thermoplastic, PVC, Reinforced  
**Deck Type II:** Wood, Insulated  
**Deck Description:** <sup>19</sup>/<sub>32</sub>" or greater plywood or wood plank  
**System Type D(1):** Membrane mechanically attached over preliminarily fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Polyisocyanurate HP-H or InsulBase, Insulfoam SP, R-Tech, R-Tech Fan-Fold Minimum 1.5" thick	N/A	N/A

**Note: All layers of insulation and base sheet shall be simultaneously attached. See base sheet below for fasteners and density. Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation shall have preliminary attachment, prior to the installation of the roofing membrane. At an application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Vapor Retarder:** (Optional) Any UL or FMRC approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Barrier (optional):** <sup>1</sup>/<sub>4</sub>", <sup>3</sup>/<sub>8</sub>", <sup>1</sup>/<sub>2</sub>", or <sup>5</sup>/<sub>8</sub>" gypsum, Dens-Deck, Securock, FR Base Sheet, G2 Base Sheet or G3 Cap (flipped)

**Membrane:** Sure-Flex, Reinforced 50, 60 or 80 mil membrane secured through the preliminarily attached insulation as specified below.

**Fastening:** HP-X Fasteners with Piranha Plates 6" o.c. through the membrane in the 5½" side lap in rows spaced 81" o.c. followed by applying a 1½" wide heat weld.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7)



## **WOOD DECK SYSTEM LIMITATIONS:**

1. A slip sheet is required with Ply 4 and Ply 6 when used as a mechanically fastened base or anchor sheet.
2. The membrane can be identified using the identification code printed outside the splice overlap area (visible every 50') or within the splice area. The code begins with either 9 or 91 to designate the plant. The next three letters designate the material and color. The next six numbers designate the date of manufacture (year/month/day). The next letter designates the shift and the last number designates the machine. In addition to this identification code, the letters "CCM" are also printed within the splice overlap area.



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No: 17-0706.09  
Expiration Date: 08/24/21  
Approval Date: 12/20/18  
Page 7 of 7