



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Rust-Oleum Corporation
11 E. Hawthorn Pkwy
Vernon Hills, IL 60061

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Premium Elastomeric 880 Roof Coating

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.

The submitted documentation was reviewed by Alex Tigera.



NOA No.: 20-0608.02
Expiration Date: 06/24/26
Approval Date: 06/24/21
Page 1 of 6

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Materials: Elastomeric

SCOPE:

This approves “**Premium Elastomeric 880 Roof Coating**” as described in this Notice of Acceptance, designed to comply with the Florida Building Code.

PRODUCT DESCRIPTION:

<u>Manufactured by Applicant</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Premium Elastomeric 880 Roof Coating	1, 5 or 53 gal.	ASTM D6083	Liquid-applied, elastomeric roofing material.

MANUFACTURING LOCATION:

1. Waupun, WI

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC, LLC	4p-RUST-20-SSLAP-01.A.R1	ASTM D6083	05/12/21

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or the Applicable Building Code in order to properly evaluate the installation of this system.



PHYSICAL PROPERTIES OF COMPONENTS:

Trade name:	Premium Elastomeric 880 Roof Coating
Thickness:	See Systems Approvals below.
Specifications:	ASTM D 6083
Description:	Coating system used for waterproofing and weatherproofing roofs.
Container Size:	1, 5, or 53 gallons. Note all cautions on container label.
Systems Approvals:	Methods of application and quantities shall comply with specific Roof Assembly, Product Control Notice of Acceptance.

APPROVED MAINTENANCE COATING APPLICATION:

Substrate:	Kynar Coated Metal
Preparation:	The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with Rust-Oleum. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.
Surface Treatment:	The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.
Foundation Coating:	Premium Elastomeric 880 Roof Coating is to be applied at 1 gal./100 ft ² (16 wet mils). Wait 12-24 hours before applying top coat. The coverage rates shown are intended as minimum application requirements. The surface dictates actual coverage needed. On metal roofs with irregular panel and rib design, multiply feet by 1.15 to calculate actual surface area to be coated.
Top Coat:	Finish Coat as described above in the "Foundation Coating" section is to be applied at 1 gal./100 ft ² (16 wet mils).
Substrate:	Galvanized Metal
Preparation:	The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.
Surface Treatment:	The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.
Foundation Coating:	Prime with Rust-Oleum 115 Hybrid Epoxy 1K Primer. 115 Hybrid Epoxy 1K Primer applies at .5 gal./100 ft ² square feet per gallon (8 wet mils). Wait 12-24 hours before applying top coat. The coverage rates shown are intended as minimum application requirements. The surface dictates actual coverage needed. On metal roofs with irregular panel and rib design, multiply feet by 1.15 to calculate actual surface area to be coated.
Top Coat:	Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1 gal./100 square feet for the 1st coat and 1 gal./100 square feet for the 2nd coat at 16 wet mils per coat.

Substrate: **Aluminum**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Premium Elastomeric 880 Roof Coating is to be applied at 1 gal./100 ft² (16 wet mils). Wait 12-24 hours before applying top coat. The coverage rates shown are intended as minimum application requirements. The surface dictates actual coverage needed. On metal roofs with irregular panel and rib design, multiply feet by 1.15 to calculate actual surface area to be coated.

Top Coat: Finish Coat as described above in the "Foundation Coating" section is to be applied at 1 gal./100 ft² (16 wet mils).

Substrate: **Existing (Rusty) Metal**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Prime with Rust-Oleum 115 Hybrid Epoxy 1K Primer. 115 Hybrid Epoxy 1K Primer applies at .5 gal./100 ft² square feet per gallon (8 wet mils). Wait 12-24 hours before applying top coat. The coverage rates shown are intended as minimum application requirements. The surface dictates actual coverage needed. On metal roofs with irregular panel and rib design, multiply feet by 1.15 to calculate actual surface area to be coated.

Top Coat: Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1 gal./100 square feet for the 1st coat and 1 gal./100 square feet for the 2nd coat at 16 wet mils per coat.

Substrate: **Smooth Built-Up Roof System**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Prime with Rust-Oleum 130 Urethane Acrylic Roof Primer. 130 Urethane Acrylic Roof Primer applies at square 75-125 feet per gallon.

Top Coat: Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1 gal./100 square feet for the 1st coat and 2 gal./100 square feet for the 2nd coat at 16 wet mils per coat



Substrate: **Granule Surfaced SBS Modified Bitumen Roof System**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Prime with Rust-Oleum 130 Urethane Acrylic Roof Primer. 130 Urethane Acrylic Roof Primer applies at square 75-125 feet per gallon.

Top Coat: Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1 gal./100 square feet for the 1st coat and 2 gal./100 square feet for the 2nd coat at 16 wet mils per coat.

Substrate: **EPDM Single-Ply Roof System**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Primer: Prime with Rust-Oleum 105 Single Ply Adhesion Primer. 105 Single Ply Adhesion Primer applies 300-400 square feet per gallon.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Prime with Rust-Oleum 105 Single Ply Adhesion Primer. 105 Single Ply Adhesion Primer applies 300-400 square feet per gallon.

Top Coat: Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1.5 gal./100 square feet for the 1st coat and 1.5 gal./100 square feet for the 2nd coat at 24 wet mils per coat.

Substrate: **TPO Single-Ply Roof System**

Preparation: The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.

Primer: Prime with Rust-Oleum 105 Single Ply Adhesion Primer. 105 Single Ply Adhesion Primer applies 300-400 square feet per gallon.

Surface Treatment: The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.

Foundation Coating: Prime with Rust-Oleum 105 Single Ply Adhesion Primer. 105 Single Ply Adhesion Primer applies 300-400 square feet per gallon.

Top Coat: Apply 2 coats of Premium 880 Elastomeric Roof Coating. Apply 1.5 gal./100 square feet for the 1st coat and 1.5 gal./100 square feet for the 2nd coat at 24 wet mils per coat.



- Substrate:** Acrylic Elastomeric Coating
- Preparation:** The surface shall be clean, sound and dry prior to application of Premium Elastomeric 880 Roof Coating. All surface preparation, and repairs, shall be in compliance with the Rust-Oleum's published application instructions and current Miami-Dade Notice of Acceptance.
- Surface Treatment:** The base of all roof penetrations and curbs, i.e. stacks, vents, etc., must be sealed using Rust-Oleum Roofing Seam Sealer or Rust-Oleum Elastomeric Roof Patch at the rate of 30 - 40 lineal ft./gal.
- Foundation Coating:** Apply Premium Elastomeric 880 Roof Coating at 1 to 1½ gal./100 ft² (16-24 wet mils). Allow first coat to fully cure prior to the application of the second coat.
- Top Coat:** Finish Coat as described above in the "Foundation Coating" section is to be applied at 1 to 1½ gal./100 ft² (16-24 wet mils).

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. All products shall be applied in strict compliance with Manufacturer's published application instructions.
3. Rust-Oleum products shall not be applied in inclement weather conditions.
4. Rust-Oleum shall not be covered with stone chips, screeds, tiles or soil.
5. Rust-Oleum shall not be applied over existing gravel surfaces.
6. Approved primer is required on all unprotected iron and steel and previously painted surfaces.
7. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
8. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Product Control upon request.
9. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



10. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance
11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
12. The use of a reinforcing fabric in a maintenance coating is only to enhance the coatings ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.

END OF THIS ACCEPTANCE

