



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

PrimeSource Building Products, Inc.
333 Manley Street
West Bridgewater, MA 02379

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: PrimeSource Grip-Rite ShingleLayment® Underlayment System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 23-0614.03 and consists of pages 1 through 5.
The submitted documentation was reviewed by Alex Tigera.

09/19/24



NOA No.: 24-0610.02
Expiration Date: 02/22/29
Approval Date: 09/19/24
Page 1 of 5

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

TRADE NAMES OF PRODUCT MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Grip-Rite ShingleLayment® 15-Pro <i>(Manufacturing Location #1)</i>	4' x 250' rolls	ASTM D8257	Synthetic roofing underlayment comprised of a woven substrate of 8x8 scrim polypropylene, with the bottom surface coated with polypropylene and the top surface coated with a non-woven spun bonded polypropylene.
Grip-Rite ShingleLayment® HT <i>(Manufacturing Location #1)</i>	3' x 67' rolls	TAS 103	Self-adhering, synthetic roof underlayment. Designed as a shingle, tile, and metal roofing underlayment.

MANUFACTURING LOCATION:

- Chengyang, Qingdao, China

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
NEMO ETC, LLC.	4j-PSBP-22-SSUDL-03.A	ASTM D8257	10/04/22
	4j-PSBP-23-SSUDL-03.A	TAS 103	09/29/23
	4a-PSBP-22-LSWUS-01.C	UL 1897	06/14/23
	4a-PSBP-22-LSWUS-01.A	UL 1897	03/17/23



NOA No.: 24-0610.02
Expiration Date: 02/22/29
Approval Date: 09/19/24
 Page 2 of 5

APPROVED ASSEMBLIES:

Deck Type 1:	Wood
Deck Description:	15/32" APA rated, 32/16 span rating, CDX, 4-ply or greater plywood or wood plank secured to supports spaced 24" o.c. and blocked at 4' o.c. Secure plywood with #8 wood screws spaced 6" o.c. at supports and blocking.
System E(1):	Base sheet mechanically fastened to deck, subsequent membrane self-adhered.

All General and System Limitations shall apply.

Base Sheet:	Grip-Rite ShingleLayment® 15-Pro applied in single coverage method parallel to the eave with minimum 4" horizontal laps and minimum 6" vertical laps applied as specified below.
Fastening:	Mechanically fastened with approved Trufast VERSA-FAST Fasteners and Trufast VERSA-FAST Metal Plates with three fasteners per plate in a triangular pattern 6" o.c. at the 4" side laps and 12" o.c. at three equally spaced rows in the field of the sheet.
Membrane:	<p>Grip-Rite ShingleLayment® HT, self-adhered with minimum 2" horizontal laps and minimum 6" vertical laps. Place the first course of membrane parallel to the eave, rolling the membrane to obtain maximum contact. Remove the release liner as the membrane is applied.</p> <p>When used in Tile roof systems the cap sheet shall be back nailed to deck with approved annular ring shank nails and caps at a maximum 12" o.c. at the side laps and 6" o.c. at the end laps. No nails or tin caps shall be exposed.</p>
Surfacing:	<p>Approved for asphalt shingle, mechanically fastened roof tile, foam-adhered roof tile, non-structural metal roofing, wood shakes & shingles or slate roof assemblies as specified within the Roof System NOA.</p> <p>For tile roof assemblies, refer to RAS 118, 119 or 120 and the tile manufacturer's NOA. For foam-adhered tile roof assemblies, approved for use with DuPont's TILE BOND™ Roof Tile Adhesive and ICP's Polyset® AH-160.</p>
Underlayment Uplift Design Pressure:	-52.5 psf.*

* Underlayment Uplift Design Pressure rating above is included for additional analysis of the underlayment assembly only by the Authority Having Jurisdiction. This value does not include the roof system. Refer to roof system NOA for maximum design pressure of the final roof assembly.



Deck Type 1: Wood
Deck Description: 15/32" APA rated, 32/16 span rating, CDX, 4-ply or greater plywood or wood plank secured to supports spaced 24" o.c. and blocked at 4' o.c. Secure plywood with #8 wood screws spaced 6" o.c. at supports and blocking.
System F(1): Membrane adhered direct to deck.

All General and System Limitations shall apply.

Membrane: Grip-Rite ShingleLayment® HT, self-adhered with minimum 2" horizontal laps and minimum 6" vertical laps. Place the first course of membrane parallel to the eave, rolling the membrane to obtain maximum contact. Remove the release liner as the membrane is applied.

When used in Tile roof systems the cap sheet shall be back nailed to deck with approved annular ring shank nails and caps at a maximum 12" o.c. at the side laps and 6" o.c. at the end laps. No nails or tin caps shall be exposed.

Surfacing: Approved for asphalt shingle, mechanically fastened roof tile, foam-adhered roof tile, non-structural metal roofing, wood shakes & shingles or slate roof assemblies as specified within the Roof System NOA.

For tile roof assemblies, refer to RAS 118, 119 or 120 and the tile manufacturer's NOA. For foam-adhered tile roof assemblies, approved for use with DuPont's **TILE BOND™ Roof Tile Adhesive** and ICP's **Polyset® AH-160**.

**Underlayment
Uplift Design
Pressure:**

-75 psf.*

*** Underlayment Uplift Design Pressure rating above is included for additional analysis of the underlayment assembly only by the Authority Having Jurisdiction. This value does not include the roof system. Refer to roof system NOA for maximum design pressure of the final roof assembly.**



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. Grip-Rite ShingleLayment® Underlayments shall be installed in strict compliance with applicable Building Code.
3. Grip-Rite ShingleLayment® Underlayments shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
4. The Grip-Rite ShingleLayment® HT two-ply underlayment system may be used in asphalt shingle, mechanically fastened tile, foam-adhered tile, wood shake & shingle, quarry slate or non-structural metal roof applications.
5. Grip-Rite ShingleLayment® Underlayments shall not be hot mopped, refer to manufacturer's published literature for product compatibility.
6. Grip-Rite ShingleLayment® Underlayments shall not be applied over an existing roof membrane as a recover system.
7. Grip-Rite ShingleLayment® 15-Pro shall not be left exposed as a temporary roof for longer than 90 days of application. Grip-Rite ShingleLayment® HT shall not be left exposed as a temporary roof for longer than 180 days of application.
8. Grip-Rite ShingleLayment® Underlayments are components used in roof assemblies. Roof assemblies are approved under a specific Notice of Acceptance. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
9. Grip-Rite ShingleLayment® Underlayments may be used with any approved roof covering Notice of Acceptance listing Grip-Rite ShingleLayment® product(s) as a component part of an assembly in the Notice of Acceptance. If Grip-Rite ShingleLayment® Underlayment are not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
10. Flash vent pipes, stacks, chimneys and penetrations in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.
11. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 24-0610.02
Expiration Date: 02/22/29
Approval Date: 09/19/24
Page 5 of 5