



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

Simon Roofing and Sheet Metal Corporation
dba SR Products
70 Karago Avenue
Youngstown, OH 44512

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SR Roof Maintenance Coatings & Cements

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA #23-0711.08 and consists of pages 1 through 11.
The submitted documentation was reviewed by Alex Tigera.

09/12/24



NOA No.: 24-0710.02
Expiration Date: 09/12/29
Approval Date: 09/12/24
Page 1 of 11

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Asphalt, Elastomeric

SCOPE:

This approves “SR Roof Maintenance Coatings & Cements” as a roof maintenance coatings, manufactured by Simon Roofing and Sheet Metal Corporation dba SR Products, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone of the Florida Building Code.

MANUFACTURING LOCATIONS:

1. Struthers, OH

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriter Laboratories, Inc.	R19353	UL 790	04/28/11
Factory Mutual Research Corp.	3008025	Class 4470	06/04/01
	3008019	Class 4470	05/17/02
	3054570	Class 4470	04/24/15
Momentum Technologies, Inc.	JX23C6A	ASTM D 3019	04/20/16
	JX07G7A	ASTM D 1227	07/27/17
	CX05A8A	ASTM D 903	01/31/18
	CX16A8A	ASTM D 4586	03/16/18
PRI Construction Materials Technologies, LLC.	SRP-008-02-01	TAS 114-H	10/19/05
	SRP-008-02-02	TAS 114-H	10/19/05
	SRP-041-02-01	ASTM D 3019	05/14/12
Trinity ERD	S31650.03.11	Adhesion Testing	03/15/11
	S35760.02.13	Physical Properties	02/27/13
	SC6860.09.14	Adhesion Testing	09/24/14
NEMO ETC, LLC	4p-SIM-19-SSLAP-01.A	ASTM D 6083	08/02/19
	4p-SIM-20-SSLAP-01.A	Various	05/05/20
	4p-SIM-19-SSLAP-02.A	ASTM D 6083	06/08/20
	4p-SIM-21-SSLAP-01.A	Various	01/19/22
	4p-SIM-22-SSLAP-01.A	Various	02/27/24
	4p-SIM-22-SSLAP-01.B	ASTM D 6083	07/02/24
	4p-SIM-22-SSLAP-01.C	TAS 139	08/16/24
	4p-SIM-22-SSLAP-01.D	ASTM D2824	02/27/24
	4p-SIM-22-SSLAP-01.E	Various	07/01/24



PHYSICAL PROPERTIES OF COMPONENTS

Trade names: SuperiorFlex™ Seal Plus
Specifications: ASTM D 3019 Type III
Description: A polymer-modified, asphalt-based, cold-applied roofing adhesive. For use to bond gravel to BUR roof systems at an application rate of 5gal./100 sq. ft. and 3 – 6 gal./100 sq. ft. as a coating on BUR and modified bituminous membrane at application rate of 2 – 3 gal./100 sq. ft..
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SR Flood Coat
Specifications: ASTM D 1227, Type II
Description: A one-component roof coating comprised of refined asphalt, clay emulsifiers and non-asbestos fibers.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SR Sun-Gard Plus Aluminum Roof Coating
Specifications: ASTM D 2824 Type I
Description: A brush or spray grade asphalt surfacing material containing aluminum pigment to provide weathering protection over Built-Up and Modified Bitumen roof systems. Apply at the rate of 1-2 gal/100 sq. ft.
Container Size: 5 and 55 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SuperiorFlex Flashing Cement
Specifications: ASTM D 4586 Type I, Asbestos Free
Description: A thick smooth trowel grade asphalt based cement used in the construction of fiberglass or organic built-up roofing. Generally applied in 1/8” to 1/4” thickness, it may also be used for repairs or in conjunction with cotton, polyester, or fiberglass reinforcing mesh.
Container Size: 3, 5 and 55 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SuperiorFlex Seal O Plus
Specifications: ASTM D 3019 Type I
Description: An asbestos free blend of selected asphalts, mineral fillers and refined solvents lap cement.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SuperiorFlex™ Seal Max
Specifications: ASTM D 3019 Type I
Description: An asbestos free blend of coal tar pitch and epoxy resin lap adhesive.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SuperiorFlex™ Seal MG Plus
Specifications: ASTM D 3019 Type III
Description: An asbestos free blend of selected asphalts, mineral fillers, polymers, glass fiber and refined solvents roof coating.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: Wite Brite Coating, CPM Coating
Specifications: ASTM D 6083
Description: An acrylic elastomeric roof coating.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: Wite Brite Elastomeric Coating
Specifications: ASTM D 6083
Description: An acrylic elastomeric roof coating.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



Trade names: Wite Brite Elastomeric Coating – Contrast FR, CPM Coating FR
Specifications: ASTM D 6083
Description: An acrylic elastomeric roof coating.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: Wite Brite Cement
Specifications: TAS 139-95
Description: An acrylic elastomeric roof cement.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: Wite Brite AS Cement
Specifications: Proprietary
Description: A SEBS thermoplastic rubber mastic roofing cement.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: A thick smooth trowel grade polymer based cement used in the construction of fiberglass, polyester or organic built-up roofing. Generally applied in 1/8” to 1/4” thickness, it may also be used for repairs or in conjunction with cotton, polyester, or fiberglass reinforcing mesh.

Trade names: Wite Brite Hi Bild Flashing
Specifications: Proprietary
Description: A SEBS thermoplastic rubber mastic roofing cement.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: A thick smooth trowel grade polymer based cement used in the construction of fiberglass, polyester or organic built-up roofing. Generally applied in 1/8” to 1/4” thickness, it may also be used for repairs or in conjunction with cotton, polyester, or fiberglass reinforcing mesh.

Trade names: Wite Brite EnviroGreen Cement
Specifications: Proprietary
Description: A thermoplastic rubber mastic roofing cement.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: A thick smooth trowel grade polymer based cement used in the construction of fiberglass, polyester or organic built-up roofing. Generally applied in 1/8” to 1/4” thickness, it may also be used for repairs or in conjunction with cotton, polyester, or fiberglass reinforcing mesh.



Trade names: Wite Brite CLP FR
Specifications: ASTM D 6083
Description: An acrylic elastomeric roof coating.
Container Size: 5 gallons. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SR Epoxy Adhesive
Specifications: Proprietary
Description: A two-component waterproofing roof adhesive.
Container Size: 3 gallons of Part A and 1 gallon of Part B. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SR Insulation Adhesive
Specifications: Proprietary
Description: A two-component modified coal tar epoxy roof adhesive.
Container Size: 2.5 gallons of Part A and 2.5 gallons of Part B. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.

Trade names: SR Mono Epoxy
Specifications: Proprietary
Description: A two-component waterproofing roof adhesive.
Container Size: 2.5 gallons of Part A and 2.5 gallons of Part B. Note all precautions on container.
Systems Approvals: Methods of application and quantities shall comply with the specific Roof Assembly, Product Control Notice of Acceptance.



EXISTING SUBSTRATES APPLICATIONS:

Substrate: Smooth Surfaced BUR, Gravel Surfaced BUR, Modifies Bituminous Membrane Smooth, Modified Bituminous Membrane-Granule Surfaced.

Preparations: Remove all loose contaminants and debris by broom or blower.

First Coat: Apply SuperiorFlex Seal Max at 2 – 2.5 gal/100ft²

Second Coat: Apply SuperiorFlex Seal MG Plus at 5 gal/100ft².

Finish Coat: Apply SR Sun-Gard Plus Aluminum Roof coating at 1 gal/100ft².

Substrate: Smooth Surfaced BUR, Granule Surfaced BUR, Modifies Bituminous Membrane Smooth, Modified Bituminous Membrane-Granule Surfaced

Preparations: Remove all loose contaminants and debris by broom or blower.

First Coat: Apply SuperiorFlex Seal Max at 2 – 2.5 gal/100ft²

Second Coat: Apply SuperiorFlex Seal MG Plus at 5 gal/100ft².

Finish Coat: Apply Wite Brite Elastomeric Coating in 2 coats at 1.5 gal/100ft².

Substrate: Single Ply TPO or Single Ply PVC Roofing Membrane.

Preparations: Remove all loose contaminants and debris by broom or blower.

Primer: Apply Wite Brite EnviroGreen Primer at 0.5 gal/100ft²

First Coat: Apply SuperiorFlex Seal Max at 2 – 2.5 gal/100ft²

Second Coat: Apply SuperiorFlex Seal MG Plus at 5 gal/100ft².

Finish Coat: Apply SR Sun-Gard Plus Aluminum Roof coating at 1 gal/100ft².

Substrate: Single Ply TPO or Single Ply PVC Roofing Membranes.

Preparations: Remove all loose contaminants and debris by broom or blower.

Primer: Apply Wite Brite EnviroGreen Primer at 0.5 gal/100ft²

First Coat: Apply SuperiorFlex Seal Max at 2 – 2.5 gal/100ft²

Second Coat: Apply SuperiorFlex Seal MG Plus at 5 gal/100ft².

Finish Coat: Apply Wite Brite Elastomeric Coating in 2 coats at 1.5 gal/100ft².

Substrate: Metal Roofs, Smooth Surfaced BUR, Granule Surfaced BUR, Granule Surfaced APP Modified Bitumen or Granule Surfaced SBS Modified Bitumen Membranes.

Preparations: Remove all loose contaminants and debris by broom or blower.

First Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft²

Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft².



Substrate: Single Ply TPO, Single Ply PVC, Single Ply EPDM Roofing Membranes.
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
First Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft².
Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.
Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft².

Substrate: Smooth Surfaced BUR, Granule Surfaced APP Modified Bitumen, Granule Surfaced SBS Modified Bitumen Membranes.
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
(Optional)
First Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft².
Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.
Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 gal/100ft².

Substrate: Galvanized Steel.
Preparations: Remove all loose contaminants and debris by broom or blower.
Finish Coat: Apply Wite Brite Coating, CPM Coating at 1.0 gal/100ft².

Substrate: Galvanized Steel, CLP+ FR Membrane.
Preparations: Remove all loose contaminants and debris by broom or blower.
Base Coat: Apply Wite Brite CLP FR at 1.5 gal/100ft².
Finish Coat: Apply Wite Brite Elastomeric Coating at 3.0 gal/100ft².



Substrate: **Single Ply TPO, Single Ply PVC, Single Ply EPDM Roofing Membranes.**
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
(Optional)
First Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².
Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.
Second Coat: Apply Wite Brite Elastomeric Coating – Contrast FR, CPM Coating FR at 1.5 to 2 gal/100ft².
Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Substrate: **Granule Surfaced APP Modified Bitumen or Granule Surfaced SBS Modified Bitumen Membranes.**
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
(Optional)
First Coat: Apply Wite Brite Elastomeric Coating – Contrast FR, CPM Coating FR at 1.5 to 2 gal/100ft².
Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Substrate: **Smooth Surfaced BUR, Smooth Surfaced APP Modified Bitumen Membrane, Smooth Surfaced SBS Modified Bitumen Membranes, Granule Surfaced APP Modified Bitumen or Granule Surfaced SBS Modified Bitumen Membrane.**
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
(Optional)
First Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².
Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.
Second Coat: Apply Wite Brite Elastomeric Coating – Contrast FR, CPM Coating FR at 1.5 to 2 gal/100ft².
Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Substrate: **Smooth Surfaced BUR, Smooth Surfaced APP Modified Bitumen Membrane.**
Preparations: Remove all loose contaminants and debris by broom or blower.
Primer: Apply Wite Brite Primer at 1/2 gal/100ft².
(Optional)
First Coat: Apply SR Flood Coat at 2 to 3 gal/100ft².
Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.
Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².
Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².



Substrate: Granule Surfaced APP Modified Bitumen or Granule Surfaced SBS Modified Bitumen Membranes.

Preparations: Remove all loose contaminants and debris by broom or blower.

**Primer:
(Optional)** Apply Wite Brite Primer at 1/2 gal/100ft².

First Coat: Apply SR Flood Coat at 3 to 4 gal/100ft².

Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.

Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Substrate: Granule Surfaced BUR.

Preparations: Remove all loose contaminants and debris by broom or blower.

**Primer:
(Optional)** Apply Wite Brite Primer at 1/2 gal/100ft².

First Coat: Apply SR Flood Coat at 8 to 12 gal/100ft².

Fabric: With the first coat still wet, lay the SR Poly Plus 40 reinforcement fabric into the Wite Brite Elastomeric coating.

Second Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².

Finish Coat: Apply Wite Brite Elastomeric Coating at 1.5 to 2 gal/100ft².



LIMITATIONS

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. SR Products shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. SR Products shall be applied as specified herein and in accordance with manufacturer's published application instructions.
8. The use of a reinforcing fabric in a maintenance coating is only to enhance the coating's ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

