



September 6, 2024

**RESPONSE LETTER NO. 1 TO REQUEST FOR INFORMATION**

Project Title: **Station 5, Car Lift Replacement**  
Project No.: **ID-0000000564**

**Email from Mr. Tamara Ferrer, from Jobbers Equipment Warehouse; on September 4, 2024, at 3:19 PM (Email Attached).**

**QUESTION No.1: The unit CL10V3-2-QC won't fit in that building, please reconfirm the building dimensions.**

**ANSWER No.1:** The lift will not fit in its current state. The lift was purchased with an optional 2' extension, however, we believe it doesn't need to be used. We are having a second meeting at the site scheduled for September 19, 2024 at 10:00 AM. Please have a representative to attend to this meeting. The overall roof height is 12 feet in between trusses and 11' 6" at the bottom of the truss.

**END OF REQUEST FOR INFORMATION No. 1**

Sincerely,

Alfredo E. Munoz, P.E.  
Program Management Manager, Fleet Management Division  
Internal Services Department (ISD)

AM:fp

cc:

Frances Perez-TeXidor, ISD	Caesar Suarez, SBD
Chris DiGiacomo, ISD	Pete Moolah
Laurie Johnson, ISD	John Sanso
Project File	Clerk of the Board

**From:** [solutions.jobbersmiami.com](mailto:solutions.jobbersmiami.com)  
**To:** [Muñoz, Alfredo \(ISD\)](#)  
**Cc:** [Clerk of the Board \(COC\); Perez Texidor, Frances \(ISD\)](#)  
**Subject:** RE: Project No. ID-0000000564- Station 5, Lift Installation  
**Date:** Wednesday, September 4, 2024 12:00:36 PM

---

EMAIL RECEIVED FROM EXTERNAL  
SOURCE

Good morning, Alfredo

The unit CL10V3-2-QC won't fit in that building.  
Please reconfirm the building dimensions.

Thanks & Regards

\*\*\*PLEASE REPLY ALL\*\*\*

Tamara Ferrer, Sales Assistant  
Jobbers Equipment Warehouse  
5440 NW 78 Avenue  
Miami, FL 33166  
Office: 305 592-8730  
Fax: 305 592-6571

---