



MIAMI-DADE COUNTY, FLORIDA
HERBERT S. SAFFIR PERMITTING AND INSPECTION CENTER


Department of Regulatory and Economic Resources
Board and Code Administration Division

11805 SW 26th Street (Coral Way) • Room 230
MIAMI, FLORIDA 33175-2474
(786) 315-2509 FAX (786) 315-2560

www.miamidade.gov/building

MEMO

TO: ALL BUILDING OFFICIALS IN MIAMI-DADE COUNTY

FROM: Secretary of the Board 
Board of Rules and Appeals (BORA)

DATE: March 24, 2022

SUBJECT: BORA Interpretation
40 Year Electrical Recertification Thermography Inspector Requirements

At their meeting of March 17, 2022, the Board of Rules and Appeals (BORA) considered an interpretation to their 40-Year Electrical Recertification Guidelines regarding the new thermography inspector requirements.

The interpretation was sought to clarify if the inspector performing the thermographic inspection requires having 7 years of commercial electrical experience in addition to the Level II Infrared thermographer certification.

Upon discussion, the Board agreed and interpreted that the Level II and the 7 years of experience is necessary. ***However, the 7 years of experience does not need to be acquired after the Level II certification.*** Therefore, an inspector could have the 7 years of experience indicted in the guidelines, and then get certified as a Level II thermographer by being qualified and trained to recognize and report thermal anomalies.

If you have any additional questions on this matter, please contact John T. Hall, Senior Code Officer at (786) 315-2557.