



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Polyglass USA, Inc.
1111 W. Newport Center Drive
Deerfield Beach, FL 33442

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Polyglass Acrylic Coatings

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 22.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 20-0611.01
Expiration Date: 07/30/25
Approval Date: 07/30/20
Page 1 of 22

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements and Coatings
Fire Classification: See General Limitation #1

SCOPE:

This approves **Polyglass Acrylic Coatings**, as manufactured by Polyglass USA, Inc. and as described in this Notice of Acceptance. This product has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

MANUFACTURING LOCATION

1. Winter Haven, FL
2. Phoenix, AZ

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>	
Trinity ERD	PLYG-SC9540.12.15-R2	ASTM D6083	02/11/16	
PRI Construction Materials Technologies Inc.	PUSA-158-02-01	ASTM D6083	04/17/17	
	PUSA-159-02-01	ASTM D6083	04/07/17	
	PUSA-149-02-01	ASTM D6083	04/17/17	
	PUSA-211-02-01	Proprietary	05/02/17	
	PUSA-147-02-01	ASTM D6083	05/08/17	
	PUSA-175-02-01	Proprietary	05/08/17	
	PUSA-248-02-01	ASTM D6083	08/22/18	
	PUSA-247-02-01	ASTM D6083	08/22/18	
	PUSA-252-02-01	ASTM D6083	08/22/18	
	PUSA-253-02-01	ASTM D6083	08/22/18	
	PUSA-249-02-01	ASTM D6083	08/22/18	
	PUSA-250-02-01	ASTM D6083	08/22/18	
	PUSA-256-02-01	ASTM D6083	06/21/19	
	PUSA-266-02-01	ASTM D6083	06/21/19	
		708T0012	Proprietary	7/22/19
		708T0011	Proprietary	7/22/19
		708T0008	ASTM D 6083	10/25/19
		708T0007	ASTM D6083	10/30/19
		708T0020	ASTM D 6083	10/30/19
		708T0022	ASTM D6083	10/30/19
	708T0018	ASTM D 6083	10/30/19	
	708T0025	ASTM D 6083	10/30/19	
	708T0016	ASTM D6083	10/30/19	
	708T0017	ASTM D6083	10/30/19	
	708T0021	ASTM D6083	10/30/19	
	708T0035	ASTM D6083	1/09/2020	



NOA No.: 20-0611.01
Expiration Date: 07/30/25
Approval Date: 07/30/20
Page 2 of 22

PHYSICAL PROPERTIES OF COMPONENTS:

- Trade name:** PG 700
- Application Rate:** 2 to 3 gallons per 100 sq./ft.; in 2 applications of 1 to 1.5 gallons per 100 sq/ft. Allow coating to dry between applications of each coat.
- Specifications:** ASTM D 6083
- Description:** A high quality, water-based, white or tinted elastomeric acrylic roof coating.
For application requirements refer to Approved Existing Substrates systems descriptions contained herein.
- Container Size:** 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.
- Systems Approvals:** For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2
-
- Trade name:** PG 700 QS
- Application Rate:** 2 to 3 gallons per 100 sq./ft.; in 2 applications of 1 to 1.5 gallons per 100 sq./ft. Allow coating to dry between applications of each coat.
- Specifications:** ASTM D 6083
- Description:** A high quality, water-based, quick setting, white or tinted elastomeric acrylic roof coating.
For application requirements refer to Approved Existing Substrates systems descriptions contained herein.
- Container Size:** 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.
- Systems Approvals:** For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2
-
- Trade name:** PolyBrite 60-FC
- Application Rate:** 2 to 3 gallons per 100 sq./ft.; in 2 applications of 1 to 1.5 gallons per 100 sq/ft. Allow coating to dry between applications of each coat.
- Specifications:** ASTM D 6083
- Description:** A premium grade, water-based white or tinted elastomeric acrylic roof coating.
**For application requirements refer to Approved Existing Substrates systems descriptions contained herein.*
- Container Size:** 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.
- Systems Approvals:** For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2



Trade name: PolyBrite 70
XtraFlex 70

Application Rate: 2 to 3 gallons per 100 sq./ft.; in 2 applications of 1 to 1.5 gallons per 100 sq./ft. Allow coating to dry between applications of each coat.

Specifications: ASTM D 6083

Description: A premium grade, water-based white or tinted elastomeric acrylic roof coating.
**For application requirements refer to Approved Existing Substrates systems descriptions contained herein.*

Container Size: 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2

Trade name: PolyBrite 70 QS

Application Rate: 2 to 3 gallons per 100 sq./ft.; in 2 applications of 1 to 1.5 gallons per 100 sq./ft. Allow coating to dry between applications of each coat.

Specifications: ASTM D 6083

Description: A premium grade, water-based, quick setting, white or tinted, elastomeric acrylic roof coating.
For application requirements refer to Approved Existing Substrates systems descriptions contained herein.

Container Size: 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2

Trade name: PolyBrite 71 HS

Application Rate: 1.5 gallons per 100 sq./ft.

Specifications: ASTM D 6083

Description: A high solids, premium grade, water-based, white or tinted, elastomeric acrylic roof coating.

Container Size: 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.

Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2



Trade name: PolyBrite 74
Application Rate: 18–24 wet mils (1.125 to 1.5 gallon per 100 square feet) per coat.
Specifications: Proprietary
Description: A water-based industrial rust inhibitive primer manufactured with a light blue color to easily determine coverage.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: PolyBrite 75
Application Rate: 24 wet mils (1.5 gallons per 100 square feet) per coat.
Specifications: ASTM D 6083
Description: A high tensile, superior grade, water-based, white or tinted, elastomeric acrylic roof coating.
Container Size: 5 gallon pail, 55 gallon drum or 275 gallon tote. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2

Trade name: PolyBrite 76
XtraFlex 76
Application Rate: 6-8 wet mils (1.0 gallon per 200-300 square feet).
Specifications: Proprietary
Description: A premium grade, stain blocking, water-based elastomeric acrylic base coat.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1

Trade name: PolyBrite 84
Application Rate: 24 wet mils (1.5 gallon per 100 square feet) per coat.
Specifications: Proprietary
Description: A rust inhibitive primer manufactured with a light grey color to easily determine coverage.
Container Size: 5 gallon pail. See product data sheet for specific volume. Note all precautions on container.
Systems Approvals: For systems approvals, refer to specific Roof Assembly Product Control Approval.
Manufacturing Location #1 and #2



ALL APPROVED SUBSTRATES:

All Substrate Preparation:

All surfaces to receive coatings must be sound, clean, dry and free from any foreign matter such as dirt, oils, grease or other debris that could inhibit the adhesion. Visually inspect all metal and non-metal flashings, edges, drains, valleys and through-roof penetrations and repair as needed in compliance with Polyglass current published application instructions.

NOTE: Ponding water is unfavorable; all roof systems should ensure positive drainage.

All surface preparation and product application shall be in compliance with the current Polyglass instructions.

GALVANIZED METAL ROOF SYSTEMS

For Galvanized Metal Roof Panel Systems, reference current Polyglass published specifications for treatment of gaps, seams (vertical and horizontal), joints, roof terminations, flashing, drains, scuppers skylights etc. Allow primers and base coats to dry prior to applying the next coat.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric	Top Coat (application rate)
PG 700	-	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700	PolyBrite 84 (1.5 gal./sq.)	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)	-	PG 700 QS (1-1.5 gal./sq.)
PG 700 QS	PolyBrite 84 (1.5 gal./sq.)	PG 700 QS (1.5 gal./sq.)	-	PG 700 QS (1.5 gal./sq.)
PolyBrite 60-FC	Optional: PolyBrite 74 (1 to 1.5 gal./sq.)	PolyBrite 60-FC (1 to 1.5 gal./sq.)	-	PolyBrite 60-FC (1 to 1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1 to 1.5 gal./sq.)
PolyBrite 70	Optional: PolyBrite 74 (1 to 1.5 gal./sq.)	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)

GALVANIZED METAL ROOF SYSTEMS – CONTINUED

PolyBrite 70	PolyBrite 84 (1.5 gal./sq.)	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5gal./sq.)
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5gal./sq.)
XtraFlex 70	Optional: PolyBrite 74 (1 to 1.5 gal./sq.)	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
PolyBrite 71 HS	Optional: PolyBrite 74 (1 to 1.5 gal./sq.)	PolyBrite 71 HS (1- 1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71 HS	PolyBrite 84 (1.5 gal./sq.)	PolyBrite 71 HS (1- 1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (1-1.5 gal./sq.)	-	PolyBrite 75 (1-1.5 gal./sq.)
PolyBrite 75	PolyBrite 84 (1.5 gal./sq.)	PolyBrite 75 (1-1.5 gal./sq.)	-	PolyBrite 75 (1-1.5 gal./sq.)



TPO MEMBRANE ROOF SYSTEMS

For TPO Membrane Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 60- FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1 to 1.5 gal./sq.)
PolyBrite 60- FC	-	PolyBrite 76 (2 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5gal./sq.)
PolyBrite 70	-	PolyBrite 76 (2 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
XtraFlex 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	PolyBrite 76 (2 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **



HYPALON MEMBRANE ROOF SYSTEMS

For Hypalon Membrane Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PG 700	-	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700	-	PG 700 (2 gal./sq.)	yes	PG 700 (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **
PolyBrite 71 HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71 HS	-	PolyBrite 71 HS (2.0 gal./sq.)	yes	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **

PVC MEMBRANE ROOF SYSTEMS

For PVC Membrane Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PG 700	-	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700	-	PG 700 (2 gal./sq.)	yes	PG 700 (2-3 gal./sq.) **
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)	-	PG 700 QS (1-1.5 gal./sq.)
PG700 QS	-	PG 700 QS (2 gal./sq.)	yes	PG 700 QS (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 60-FC (2.0 gal. /sq.)	yes	PolyBrite 60-FC (2-3 gal. /sq.)**
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal. /sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.)
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal. /sq.)	yes	PolyBrite 70QS (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)

PVC MEMBRANE ROOF SYSTEMS - CONTINUED				
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **
PolyBrite 71 HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71 HS	-	PolyBrite 71 HS (2.0 gal./sq.)	yes	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75		PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **



CONCRETE ROOF SYSTEMS

For Concrete Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PG 700	-	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700	-	PG 700 (2 gal./sq.)	yes	PG 700 (2-3 gal./sq.) **
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)	-	PG 700 QS (1-1.5 gal./sq.)
PG700 QS	-	PG 700 QS (2 gal./sq.)	yes	PG 700 QS (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 60-FC (2.0 gal. /sq.)	yes	PolyBrite 60-FC (2-3 gal. /sq.)**
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal. /sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.)
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal. /sq.)	yes	PolyBrite 70QS (2-3 gal./sq.) **

CONCRETE ROOF SYSTEMS - CONTINUED				
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **
PolyBrite 71HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71HS	-	PolyBrite 71 HS (2.0 gal./sq.)	yes	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **

GEORGIA-PACIFIC DENSDECK PRIME GYPSUM BOARD ROOF SYSTEMS				
For Georgia-Pacific DensDeck Prime Gypsum Board Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.				
*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.				
**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.				
Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 60-FC (2.0 gal. /sq.)	yes	PolyBrite 60-FC (2-3 gal. /sq.)**



SPRAY APPLIED POLYURETHANE FOAM ROOF SYSTEMS

For Spray Applied Polyurethane Foam Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PG 700	-	PG 700 (1-1.5 gal./sq.)	-	PG 700 (1-1.5 gal./sq.)
PG 700	-	PG700 (1-1.5 gal./sq.)	-	PG700 (2-3 gal./sq.) **
PG 700	-	PG 700 (2 gal./sq.)	yes	PG 700 (2-3 gal./sq.) **
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)		PG 700 QS (1-1.5 gal./sq.)
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)		PG 700 QS (2-3 gal./sq.) **
PG700 QS	-	PG 700 QS (2 gal./sq.)	yes	PG 700 QS (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)		PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)		PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 70 (2.0 gal. /sq.)	yes	PolyBrite 70 (2-3 gal. /sq.) **
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 70 (2.0 gal. /sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **

SPRAY APPLIED POLYURETHANE FOAM ROOF SYSTEMS - CONTINUED

PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.)
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal./sq.)	yes	PolyBrite 70QS (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **
PolyBrite 71 HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71 HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 71 HS	-	PolyBrite 71 HS (2.0 gal./sq.)	yes	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **



APP GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS

For APP Granulated Cap Sheet Mod Bit Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 60-FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal. /sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.)
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal. /sq.)	yes	PolyBrite 70QS (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **

SBS GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS

For SBS Granulated Cap Sheet Mod Bit Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PG700	-	PG 700 (1-1.5 gal./sq.)	-	PG700 (1-1.5 gal./sq.)
PG700	-	PG 700 (2 gal./sq.)	yes	PG 700 (2-3 gal./sq.) **
PG 700 QS	-	PG 700 QS (1-1.5 gal./sq.)	-	PG700 QS (1-1.5 gal./sq.)
PG 700 QS	-	PG 700 QS (2 gal./sq.)	yes	PG 700 QS (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 60-FC (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 60-FC (2 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 60-FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)

SBS GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS - CONTINUED

PolyBrite 70	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.)
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal./sq.)	yes	PolyBrite 70 QS (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **

AGED SBS GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS

For Aged SBS Granulated Cap Sheet Mod Bit Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 71 HS	-	PolyBrite 71 HS (1-1.5 gal./sq.)	-	PolyBrite 71 HS (1-1.5 gal./sq.)
PolyBrite 71 HS	-	PolyBrite 71 HS (2.0 gal./sq.)	yes	PolyBrite 71 HS (2-3 gal./sq.) **
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **

APP GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS

For APP Granulated Cap Sheet Mod Bit Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 60-FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1-1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 70 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 70 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5 gal./sq.)
PolyBrite 70	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (1-1.5 gal./sq.)	-	PolyBrite 70 QS (1-1.5 gal./sq.) **
PolyBrite 70 QS	-	PolyBrite 70 QS (2.0 gal./sq.)	yes	PolyBrite 70 QS (2-3 gal./sq.) **
XtraFlex 70	-	XtraFlex 70 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	XtraFlex 70 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **

AGED APP GRANULATED CAP SHEET MOD BIT ROOF SYSTEMS

For Aged APP Granulated Cap Sheet Mod Bit Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric*	Top Coat (application rate)
PolyBrite 75	-	PolyBrite 75 (1.5 gal./sq.)	-	PolyBrite 75 (1.5 gal./sq.)
PolyBrite 75	-	PolyBrite 75 (2.0 gal./sq.)	yes	PolyBrite 75 (2-3 gal./sq.) **



GRANULATED BUILT-UP ROOF SYSTEMS

For Granulated Built-Up Roof Systems, reference Polyglass USA published specifications for treatment of seams, terminations, counter flashings, fasteners and detail areas.

*Polyester Fabric Applications: Fully embed polyester fabric while coating is still wet keeping a minimum of 3 inch overlap. Fabric must be completely embedded in foundation coat and allowed to dry.

**Apply two equal coats at a combined rate of 2 to 3 gal./sq. by brush or spray.

Product	Primer (application rate)	Foundation Coat (application rate)	Polyester Fabric	Top Coat (application rate)
PolyBrite 60- FC	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 60-FC (1 to 1.5 gal./sq.)
PolyBrite 60-FC	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 60-FC (2-3 gal./sq.) **
PolyBrite 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	PolyBrite 70 (1-1.5gal./sq.)
PolyBrite 70	-	PolyBrite 76 (2.0 gal./sq.)	yes	PolyBrite 70 (2-3 gal./sq.) **
XtraFlex 70	-	PolyBrite 76 (1-1.5 gal./sq.)	-	XtraFlex 70 (1-1.5 gal./sq.)
XtraFlex 70	-	PolyBrite 76 (2.0 gal./sq.)	yes	XtraFlex 70 (2-3 gal./sq.) **

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Product shall be applied in strict compliance with Manufacturer's published application instructions when not in conflict with the information contained herein.
3. Coating products shall not be applied in inclement weather conditions.
4. The product listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their Roof Assembly Notice of Acceptance. If a product is not listed as part of roof assemblies Notice of Acceptance, a request may be made to the local building official or the Miami Dade County Product Control Section for approval provided that appropriate documentation is provided.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to RER upon request.
6. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



7. The use of a reinforcing fabric in a maintenance coating is only to enhance the coatings ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.
8. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 20-0611.01
Expiration Date: 07/30/25
Approval Date: 07/30/20
Page 22 of 22