



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

SOPREMA, Inc.  
310 Quadral Drive  
Wadsworth, OH 44281

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Soprema Modified Bitumen Roofing Systems over Gypsum Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 15-0709.12 and consists of pages 1 through 23.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 20-0902.13  
Expiration Date: 03/01/26  
Approval Date: 02/04/21  
Page 1 of 23

## ROOFING SYSTEM APPROVAL

Category: Roofing  
Sub-Category: Modified Bitumen  
Material: SBS  
Deck Type: Gypsum  
Maximum Design Pressure: -187.5 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Soprabase	39" x 99' (3 sq.)	ASTM D4601	Oxidized asphalt, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Soprabase S	39" x 65' (2 sq.)	ASTM D4601	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Sopra IV	36" x 180' (5 sq.)	ASTM D2178 Type IV	Type IV, fiberglass reinforced, smooth surfaced plysheet used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Sopra VI	36" x 180' (5 sq.)	ASTM D2178 Type VI	Type VI, fiberglass reinforced, smooth surfaced plysheet used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Colvent TG	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weldable strips on back side.
Colvent 180 TG	39" x 43' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side.
Colvent Flam 180 TG	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side and a plastic burn-off film surface.
Colphene Sanded	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded 3.0	39" x 33' (1sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripped.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Elastophene HS	39" x 66' (2 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene PS 3.0	39" x 49' (1.5sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene SP 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene SP 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene SP 3.0	39" x 49' (1 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene SP 3.0	39" x 49' (1 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam HS	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and plastic burn-off film on both sides. Applied by heat welding.
Colphene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Colphene 180 PS	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Flam LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Sopralene 180 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 250 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 Sanded 2.2	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
Sopralene 180 PS	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the top and sanded on the bottom.



<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Sopralene 180 PS 2.2	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 SP 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene 180 SP 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 SP 3.0	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
Sopralene 250 SP	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
Soprafix Base 612	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix Base 613	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix Base 614	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix Base 622	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
Soprafix Base 641	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopralene Flam 180	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Colphene 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Colphene 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 250 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopralene Flam 180 GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180 GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR GR 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).



<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Sopralene Flam Antirock	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Sopralast 50 TV Alu	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
Sopralast 50 TV Alu Sanded	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting sanded on the bottom and faced with aluminum foil. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene Stick	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
Colphene Stick	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
Sopralene Flam Stick	39" x 33' (1 sq.)	ASTM D6164	Self-adhered, polyester reinforced membrane with a release film on the bottom and a plastic burn-off film on the top.
Elastocol 500	various	ASTM D41	Asphalt primer.
Elastocol Stick	various	ASTM D41	Asphalt primer.
Elastocol Stick Zero	Various	ASTM D41	Asphalt primer.
ALSAN Flashing™	1.25 gallon pail or 3.75 gallon pail	Proprietary	One part polyurethane/bitumen resin, moisture cure compound.
ALSAN Polyfleece	4", 8" or 39" wide by 50' long	Proprietary	Non-woven polyester reinforcement used in the ALSAN Flashing system.
COLPLY Flashing Cement	5 gallon pail	Proprietary	Elastomeric bitumen based mastic compound.
Soprawalk	39" x 26' (3/4 sq.)	Proprietary	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and mineral granules on the top. Applied by hot asphalt, cold adhesive or ribbon stripping.
Duotack	5, 50 gallon pail	Proprietary	Two part elastomeric urethane foam adhesive.
Duotack Neo	5, 50 gallon pail	Proprietary	Two part polyurethane foam adhesive.
COLPLY Adhesive	5 gallon pail or 55 gallon drum	Proprietary	Polymer modified cold process membrane adhesive.
COLPLY EF Adhesive	5 gallon pail	Proprietary	Solvent free, polymeric adhesive.





**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
ACFoam-II, ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corporation
DensDeck	Water resistant gypsum board	Georgia Pacific Gypsum LLC
H-Shield	Polyisocyanurate foam insulation	Hunter Panels LLC
ENRGY 3	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax Operating, LLC
Sopraboard	Mineral fortified asphaltic cored coverboard	SOPREMA, Inc.
M-Shield	Polyisocyanurate foam insulation	SOPREMA, Inc.
Sopra-ISO r	Polyisocyanurate foam insulation	SOPREMA, Inc.
Sopra-ISO s, Sopra-ISO+ s	Polyisocyanurate foam insulation	SOPREMA, Inc.
Sopra-ISO x	Polyisocyanurate foam insulation	SOPREMA, Inc.

**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Trufast Twin Loc-Nail Assembled Fastener	Base ply fastening systems for lightweight concrete, gypsum or cementitious wood fiber decks		Altenloh, Brinck & Co. U.S., Inc.
2.	Trufast Twin Loc-Nail Batten Fastener	Batten bar		Altenloh, Brinck & Co. U.S., Inc.
3.	Polymer Batten Strip	Modified polymer batten bar		OMG, Inc.
4.	SOPREMA Twin Loc-Nail	Base ply fastening systems for lightweight concrete, gypsum or cementitious wood fiber decks		Soprema, Inc.
5.	Millennium One Step Foamable Adhesive	Polyurethane two component high rise insulation adhesive		H.B. Fuller Company
6.	Millennium One Step Green Foamable Adhesive	Polyurethane two component high rise insulation adhesive		H.B. Fuller Company
7.	Millennium PG-1 Low Viscosity Insulation Adhesive	Polyurethane two component high rise insulation adhesive		H.B. Fuller Company



## APPROVED SURFACING/COATING OPTIONS:

TABLE 4

Chosen components must be applied according to manufacturer's application instructions. Any coating, listed below, used as a surfacing, must be listed within a current NOA.

System Number	Manufacturer	Application
1.	Generic	Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.
2.	SOPREMA, Inc.	Gravel applied at 400 lbs./sq., adhered with COLPLY EF Adhesive, COLPLY Adhesive at 4 gal./sq.
3.	Karnak Corporation	Karnak (#97 AF) Fibered Aluminum Roof Coating applied at an application rate of 1.5 gal./sq.
4.	SOPREMA, Inc.	Cural Aluminizer applied at an application rate of 2 gal./sq.
5.	Thermo Manufacturing Systems, LLC	Super Prep Elastomeric Roof Maintenance Coating applied in two coats at an application rate of 1.5 gal./sq./coat.
6.	Quest Construction Products LLC dba United Coatings	United Coatings Roof Mate Coating, applied in one base coat at a rate of 1.5 gal./sq., and one finish coat at a rate of 1.5 gal./sq.
7.	Insulating Coatings Corporation	Astec 2000 Finish Coat applied in two base coats at a rate of 0.75 gal./sq./coat and two finish coats at a rate of 0.75 gal./sq./coat.
8.	Henry Company	HE280DC White Elastomeric Roof Coating applied in two coats at an application rate of 1 gal./sq./coat.
9.	National Coating Corp.	Acryshield® A500 applied in two coats at an application rate of 1 gal./sq./coat.
10.	SOPREMA, Inc.	R Nova Plus applied in two coats. Base coat is applied at 3 gal/sq. (1.2 L/m <sup>2</sup> ) and allowed to dry. A top coat is applied at 1 gal/sq. (0.4 L/m <sup>2</sup> ).
11.	Generic	Semi-ceramic coated colored granules.

**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>	
FM Approvals	3024311	FM 4470	11/01/06	
	3036182	FM 4470	07/31/09	
	3044801	FM 4470	02/27/12	
	3045101	FM 4470	11/05/12	
	3047439	FM 4470	07/22/13	
	3046765	FM 4470	02/15/13	
	3047351	FM 4470	10/09/14	
	3042559	FM 4470	10/18/11	
	3023458	FM 4470	07/18/06	
	3053841	FM 4470	03/27/15	
	RR201595	FM 4470	06/17/15	
UL LLC	R11436	UL 790	01/15/21	
Trinity   ERD	2761.09.03	TAS 114	09/02/03	
	2766.12.03	/TAS 114	12/01/03	
	S32840.06.10-R1	TAS 117 (B)	12/11/14	
	S43400.08.14-5	ASTM D6163	08/26/14	
	S43400.08.14-6	ASTM D6164	08/26/14	
	S43400.08.14-7-R1	ASTM D6164	11/20/14	
	S43400.09.14-9	ASTM D6164	09/02/14	
	S43400.09.14-10	ASTM D6298	09/08/14	
	S45010.02.14	ASTM D6506	02/07/14	
	S43400.08.14-4-R1	ASTM D6163	10/24/14	
	S44110.09.14-3	ASTM D6163	09/08/14	
	S44110.09.14-7C	ASTM D6164	09/02/14	
	S44220.09.14-1	ASTM D6162	09/08/14	
	S11440.11.10-4	ASTM D2178	11/17/10	
	S11440.11.10-3-R2	ASTM D4601/TAS 117-B	08/26/14	
	S44220.09.14-7A	ASTM D4601	09/08/14	
	S11440.12.10-1-R1	ASTM D6163	06/07/12	
	S32700.12.10-R2	ASTM D6162	07/07/14	
	S35860.12.11-1-R1	ASTM D2178	12/12/14	
	S35860.05.12-1-R2	ASTM D6163	03/14/13	
	S35860.05.12-2-R3	ASTM D6164	08/29/14	
	S35860.05.12-3-R1	ASTM D6164	03/14/13	
	S47160.01.14-R1	TAS 114	12/11/14	
	S43210.11.14	ASTM D1876	11/10/14	
	PRI Construction Materials Technologies, LLC	SOP-049-02-01	ASTM D1644/D2196	05/31/12
		SOP-043-02-01	ASTM D4601	02/27/12
SOP-042-02-01		ASTM D4601	02/27/12	
SOP-041-02-01		ASTM D2178	02/27/12	
SOP-040-02-01		ASTM D2178	02/27/12	
SOP-010-02-01.03		TAS-138	07/26/11	
SOP-050-02-01		ASTM D3019	07/12/12	
SOP-056-02-01		Physical Properties	09/12/12	
EATC-001-02-01		ASTM D4586	04/07/09	



**EVIDENCE SUBMITTED: (CONTINUED)**

<b><u>Test Agency/Identifier</u></b>	<b><u>Name</u></b>	<b><u>Report</u></b>	<b><u>Date</u></b>
Atlantic & Caribbean Roof	ACRC 15-048	TAS 114	01/04/16
Consulting, LLC	ACRC 15-035	TAS 114	12/16/15



## APPROVED ASSEMBLIES

- Membrane:** SBS
- Deck Type 6I:** Gypsum, Insulated
- Deck Description:** Poured Gypsum
- System Type A(1):** Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt or adhesive.

### All General and System Limitations apply.

- Anchor Sheet:** One layer Soprabase, Soprabase S, Colphene 180 Sanded, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 250 Sanded, Sopralene 250 SP, mechanically attached with 1.8" long Trufast Twin Loc-Nail Assembled Fastener or SOPREMA Twin Loc-Nails spaced 6" o.c. in min. 4" lap and 6" o.c. in two evenly spaced, staggered rows in the field.

One or more layers of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, Multi-Max FA-3, Sopra-ISO x, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
DensDeck Minimum ¼" thick	N/A	N/A
Sopraboard Minimum 1/8" thick	N/A	N/A
SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

**Note:** All insulation shall be adhered to the vapor barrier in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>, or in Duotack, Duotack Neo, Millennium One Step Foamable Adhesive, Millennium One Step Green Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in ¾" wide ribbons spaced 6" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as a final membrane substrate.

- Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero at a rate of 1 gal./sq.
- (Optional)**
- Base Sheet:** One layer of Sopralene Stick, Colphene Stick or Sopralene Flam Stick\*, self-adhered.
- Or
- One layer Colvent TG, Colvent 180 TG, Colvent Flam 180 TG\*, torch-applied.
- \*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix Base 622, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.

Or

**Ply Sheet:  
(Optional)  
(Cont.)** Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive, COLPLY Adhesive, at a rate of 1.5 gal./sq. to sand surfaced base membrane.

\*Requires torch-applied cap membrane.

**Membrane:** One layer of Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

One layer of Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive, COLPLY Adhesive at a rate of 1.5 gal./sq. to sand surfaced base membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:** -60 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 6I:** Gypsum, Insulated  
**Deck Description:** Poured Gypsum  
**System Type A(2):** Anchor sheet adhered, all layers of insulation adhered with approved asphalt or adhesive.

**All General and System Limitations apply.**

**Vapor Barrier:** One layer of Modified Sopra G, Soprabase, Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive applied in 1/2" to 3/4" wide ribbons spaced 12" o.c.

One or more layers of the following.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>H-Shield, M-Shield, Sopra-ISO r, Multi-Max FA-3, Ultra-Max, SOPRA-ISO x, ENRGY 3, H-Shield CG, Sopra-ISO+ r, M-Shield CG, ACFoam-II, ACFoam-III, SOPRA-ISO s, SOPRA-ISO+ s, ENRGY 3 AGF, ENRGY 3 CGF, EnergyGuard Polyiso Insulation Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8" thick</b>	N/A	N/A

**Note: All insulation shall be adhered to the vapor barrier in Duotack or Duotack Neo in 1/2" to 3/4" wide ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as a final membrane substrate.**

**Base Sheet:** One layer of Modified Sopra G, Soprabase, Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\* or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive, COLPLY Adhesive applied in 1/2" to 3/4" wide ribbons spaced 12" o.c. to lightweight insulating concrete.

Or

One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Colvent TG, Colvent 180 TG, Colvent Flam 180 TG\*, torch-applied.

Or

**Base Sheet:** One layer of Elastophene Stick, Sopralene Stick, Colphene Stick, Elastophene Flam Stick\* or Sopralene Flam Stick\*, self-adhered to substrate primed with Elastocol Stick Zero.

**(Continued)**

\*Requires torch-applied ply or cap membrane



**Ply Sheet:  
(Optional)** One layer of Modified Sopra G, Soprabase, Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\* or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive, COLPLY Adhesive applied at a rate of 1.5 – 2 gal./sq.

Or

One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Colvent TG, Colvent 180 TG, Colvent Flam 180 TG\*, torch-applied.

Or

One layer of Elastophene Stick, Sopralene Stick, Colphene Stick, Elastophene Flam Stick\* or Sopralene Flam Stick\*, self-adhered.

\*Requires torch-applied ply or cap membrane

**Membrane:** Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in COLPLY EF Adhesive or COLPLY Adhesive at 1.5 – 2.0 gallons/square to sand surfaced base/ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -115 psf. (See General Limitation #9.)





**Membrane:** SBS  
**Deck Type 6I:** Gypsum, Insulated  
**Deck Description:** Poured Gypsum  
**System Type D(1):** Base sheet attached over preliminary fastened insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, Multi-Max FA-3, Sopra-ISO x, Sopra-ISO r, M-Shield, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick</b>	1	See Note Below

**Note: Top insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer: (Optional)** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq., to top surface of any insulation, base or ply sheet prior to application of next layer

**Base Layer:** One layer Soprafix Base 622, Soprafix Base 612\*, Soprafix Base 613\*, Soprafix Base 614\* or Soprafix Base 641 mechanically attached with Trufast Twin Loc-Nail Assembled Fastener or SOPREMA Twin Loc-Nails spaced 6" o.c. through OMG Polymer Batten Strip, Trufast Twin Loc-Nail Batten Fastener, placed in the lap and in one row centered in the field.  
 Center fastener row is covered with an 8" wide strip of Sopralene Flam Stick\*, Sopralene Stick or Colphene Stick, self-adhered.  
 \*Requires torch-applied ply or cap membrane.

**Ply Sheet: (Optional)** Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix Base 622, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.

Or

Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive or COLPLY Adhesive at a rate of 1.5 gal./sq. to sand surfaced base membrane.  
 \*Requires torch-applied cap membrane.



**Membrane:** One layer of Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

One layer of Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive or COLPLY Adhesive at a rate of 1.5 gal./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -45 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 6I:** Gypsum, Insulated  
**Deck Description:** Poured Gypsum  
**System Type D(2):** Base sheet attached over preliminary fastened insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, Multi-Max FA-3, Sopra-ISO x, Sopra-ISO r, M-Shield, H-Shield Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck, SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick</b>	1	See Note Below

**Note: Top insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq., to top surface of any insulation, base or ply sheet prior to application of next layer  
**(Optional)**

**Base Layer:** One layer Soprafix Base 622, Soprafix Base 612\*, Soprafix Base 613\*, Soprafix Base 614\*, Sopralene Flam 180\*, Colphene Flam 180\* or Sopralene Flam 250\* mechanically attached with Trufast Twin Loc-Nail Assembled Fastener or SOPREMA Twin Loc-Nails spaced 6" o.c. through OMG Polymer Batten Strip, Trufast Twin Loc-Nail Batten Fastener, placed in the lap and in one row centered in the field. Center fastener row is covered with an 8" wide strip of Sopralene Flam Stick\*, Sopralene Stick or Colphene Stick, self-adhered.

**Ply Sheet:** One or more layers of Sopralene Flam 180\*, Colphene Flam 180\* or Sopralene Flam 250\*, torch-applied.  
**(Optional)**

**Membrane:** One layer of Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -82.5 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 6:** Gypsum, Non-Insulated  
**Deck Description:** Poured Gypsum  
**System Type E:** Base sheet mechanically fastened to substrate.

**All General and System Limitations apply.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any base or ply sheet prior to application of next layer

**Base Sheet:** Soprabase, Soprabase S, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix Base 622, Soprafix Base 612\*, Soprafix Base 613\*, Soprafix Base 614\*, Sopralene Flam 250\*, Sopralene 250 SP, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, mechanically attached with 1.8” long Trufast Twin Loc-Nail Assembled Fastener or SOPREMA Twin Loc-Nails spaced 6” o.c. in a min. 4” lap and 6” o.c. in two evenly spaced staggered rows in the field.  
\*Requires torch-applied ply or cap membrane.

**Ply Sheet:** Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene  
**(Optional)** SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix Base 622, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.

Or

Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\* or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive or COLPLY Adhesive at a rate of 1.5 gal./sq. to sand surfaced base membrane.

**Membrane:** One layer of Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

**Membrane:** One layer of Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR,  
**(Continued)** Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive or COLPLY Adhesive at a rate of 1.5 gal./sq. to sand surfaced base or ply membrane.



**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7.)



**Deck Type 6:** Gypsum, Non-Insulated  
**Deck Description:** Poured Gypsum  
**System Type F:** Base Sheet adhered to deck. Membrane subsequently adhered.

**All General and System Limitations apply.**

**Base Layer:** One layer of Modified Sopra G, Soprabase, Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\* or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive applied in ½” to ¾” wide ribbons spaced 12” o.c. to gypsum deck.  
\*Requires torch-applied ply or cap membrane.

**Ply Sheet: (Optional)** One layer of Modified Sopra G, Soprabase, Colphene Sanded, Elastophene Sanded 2.2, Elastophene Sanded 3.0, Elastophene HS, Elastophene PS\*, Elastophene PS 3.0\*, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\* or Sopralene 250 Sanded adhered in hot asphalt at 25 lbs./sq. or applied in COLPLY EF Adhesive or COLPLY Adhesive at a rate of 1.5 – 2 gal./sq.  
Or  
One layer of Elastophene Flam, Elastophene Flam 2.2, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, Colvent TG, Colvent 180 TG, Colvent Flam 180 TG\*, torch-applied  
\*Requires torch-applied ply or cap membrane.

**Membrane:** Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.  
Or  
Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in COLPLY EF Adhesive or COLPLY Adhesive at 1.5 – 2.0 gallons/square to sand surfaced ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -187.5 psf. (See General Limitation #9.)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

