



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/building/](http://www.miamidade.gov/building/)

## NOTICE OF ACCEPTANCE (NOA)

**Tremco CPG Inc.**  
3735 Green Road  
Beachwood, OH 44122

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Tremco Modified Bitumen Roofing Systems over Steel Decks

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 22-0228.24 and consists of pages 1 through 63.  
The submitted documentation was reviewed by Alex Tigera.

06/13/24



NOA No.: 22-0726.01  
Expiration Date: 07/12/26  
Approval Date: 06/13/24  
Page 1 of 63

## ROOFING SYSTEM APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Modified Bitumen
<b>Material:</b>	SBS
<b>Deck Type:</b>	Steel
<b>Maximum Design Pressure:</b>	-247.5 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
BURmastic Adhesive	5 or 55 gallons	Proprietary	Cold applied ply sheet and surfacing adhesive.
BURmastic Adhesive SF	55 gallons	Proprietary	Single-component, moisture cured urethane, solvent free cold process asphalt adhesive.
BURmastic Adhesive MC	5 gallons	Proprietary	Single-component, moisture cured urethane, solvent free cold process asphalt adhesive.
BURmastic Composite Ply HT	3' x 72'	ASTM D 4601 Type II	Asphalt coated, polyester/fiberglass reinforced base/ply sheet.
BURmastic Glass Ply	3' x 72'	ASTM D 4601 Type II	Asphalt coated, fiberglass reinforced base/ply sheet.
FAS-N-FREE	System	Proprietary	One part, solvent free insulation adhesive.
POWERply Standard FR	39' ½" x 34.5'	ASTM D 6163	Fiberglass reinforced modified-bitumen membrane.
POWERply Heavy Duty Base Sheet	36" x 36'	ASTM D 6163	Fiberglass reinforced modified-bitumen membrane.
POWERply Standard Smooth HW	39' ¾" x 32' 10"	ASTM D 6163	A glass reinforced SBS modified bitumen base sheet for heat welded applications.
POWERply Standard FR HW	39' ¾" x 32' 10"	ASTM D 6163	A fire resistant, glass reinforced SBS modified bitumen membrane surfaced with granules for use in heat weld applications.



POWERply Endure 100 Smooth	36" x 56' 8"	ASTM D 6163	Fiberglass reinforced, smooth surfaced, heat-resistant modified bitumen membrane.
POWERply Endure 200 Smooth	39' <sup>3</sup> / <sub>8</sub> " x 51' 6"	ASTM D 6164	Non-woven reinforced, smooth surfaced, polyester modified bitumen membrane.
POWERply Endure 300 Smooth	39' <sup>3</sup> / <sub>8</sub> " x 51' 6"	ASTM D 6162	Composite reinforced, smooth surfaced, modified bitumen membrane.
POWERply Endure 320 Smooth	39' <sup>3</sup> / <sub>8</sub> " x 51' 6"	ASTM D 6162	Composite reinforced, smooth surfaced, modified bitumen membrane.
POWERply Endure 100 FR	36" x 38'	ASTM D 6163	Fiberglass reinforced, granule surfaced, heat-resistant modified bitumen membrane.
POWERply Endure 200 FR	39' <sup>3</sup> / <sub>8</sub> " x 34' 5"	ASTM D 6164	Non-woven reinforced, granule surfaced, polyester modified bitumen membrane.
POWERply Endure 300 FR	39' <sup>3</sup> / <sub>8</sub> " x 34' 5"	ASTM D 6162	Composite reinforced, granule surfaced, modified bitumen membrane.
POWERply Endure 320 FR	39' <sup>3</sup> / <sub>8</sub> " x 34' 5"	ASTM D 6162	Composite reinforced, smooth surfaced, modified bitumen membrane.
POWERply Standard Cold Adhesive	5 and 55 gallons	Proprietary	Cold applied ply sheet and membrane adhesive.
THERMastic 80	60 lb. Containers	Proprietary	Polymer modified hot melt adhesive.
Premium IV	100 lb. keg	ASTM D 312	Premium grade Type IV asphalt.
THERMglass Type IV	36" x 180'	ASTM D 2178 Type IV	Type IV asphalt impregnated glass felt.
THERMglass Premium VI	36" x 180'	ASTM D 2178 Type VI	Type VI asphalt impregnated glass felt.
TREMprime WB primer	5 gallons	Proprietary	Water based roofing primer.
Tremco Low Rise Foam Insulation Adhesive	1.5 liters	Proprietary	One part, solvent free adhesive used for adhering approved insulations to approved substrates.
Tremco Low Rise Foam Insulation Adhesive (BG)	1.5 liters	Proprietary	One part, solvent free adhesive used for adhering approved insulations to approved substrates.
Tremco LR Adhesive	1.5 liters	Proprietary	One part, solvent free adhesive used for adhering approved insulations to approved substrates.
Tremco LR Adhesive (BG)	1.5 liters	Proprietary	One part, solvent free adhesive used for adhering approved insulations to approved substrates.
POWERply Endure BIO Adhesive	Part A – 5 gallons Part B – 1 gallon	Various	Two component, low odor, bio based polyurethane adhesive.



POWERply Endure BIO Adhesive TF	Part A – 3.5 gallons Part B – 0.5 gallon	Various	Two component, low odor, bio based polyurethane adhesive.
------------------------------------	---	---------	--

**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
ACFoam-II	Various	TAS 110	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ACFoam-III	Various	TAS 110	Polyisocyanurate foam insulation	Atlas Roofing Corporation
H-Shield	Various	TAS 110	Polyisocyanurate foam insulation	Hunter Panels, a div. of Carlisle Construction Materials, LLC.
EnergyGuard Polyiso Insulation	Various	TAS 110	Polyisocyanurate foam insulation	GAF
ISO 95+ GL	Various	TAS 110	Polyisocyanurate foam insulation	Holcim Solutions and Products US, LLC.
RESISTA	Various	TAS 110	Polyisocyanurate foam insulation	Holcim Solutions and Products US, LLC.
ENRGY 3	Various	TAS 110	Polyisocyanurate foam insulation	Johns Manville Corp.
Ultra-Max	Various	TAS 110	Polyisocyanurate foam insulation	Rmax, A Business Unit of Sika Corporation
Multi-Max FA-3	Various	TAS 110	Polyisocyanurate foam insulation	Rmax, A Business Unit of Sika Corporation
Structodek HD with Primed Red Coating	Various	TAS 110	High Density wood fiber insulation board	Blue Ridge Fiberboard, Inc.
DensDeck	Various	TAS 110	Water resistant gypsum board	Georgia-Pacific Gypsum, LLC
DensDeck Prime	Various	TAS 110	Water resistant gypsum board	Georgia-Pacific Gypsum, LLC
SECUROCK Gypsum-Fiber Roof Board	Various	TAS 110	Gypsum board	United States Gypsum Corp.
SECUROCK Cement Roof Board	Various	TAS 110	Gypsum board	United States Gypsum Corp.
DEXcell FA Glass Mat Roof Board	Various	TAS 110	Heavy duty coated glass mat	National Gypsum Company
MONOBOARD	Various	TAS 110	Mineral fiber insulation	ROXUL, Inc. dba ROCKWOOL



MONOBOARD PLUS	Various	TAS 110	Mineral fiber insulation	ROXUL, Inc. dba ROCKWOOL
TOPROCK DD	Various	TAS 110	Mineral fiber insulation	ROXUL, Inc. dba ROCKWOOL
Trisotech G	Various	TAS 110	Polyisocyanurate foam insulation	Tremco CPG Inc.

**APPROVED FASTENERS / ADHESIVES:**

**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	#12 Standard Roofgrip	Insulation fastener for wood and steel decks.	Various	OMG, Inc.
2.	AccuTrac Hextra	Insulation fastener for wood and steel decks.		OMG, Inc.
3.	3 in. Round Metal Plate	Galvalume AZ50 stress plate.	3" round	OMG, Inc.
4.	#14 Roofgrip	Insulation fastener for wood, steel and concrete decks.	Various	OMG, Inc.
5.	OMG Plastic Plate	Polypropylene plastic plate.	3" round	OMG, Inc.
6.	Dekfast DF-#12-PH3, Dekfast DF-#14-PH3, Dekfast DF-#15-PH3	Insulation fastener for steel and wood decks.	Various	SFS Group USA, Inc.
7.	Dekfast PLT-R-3	3" round galvalume AZ50 steel plate.	3" round	SFS Group USA, Inc.
8.	Dekfast PLT-P-R-3	3" round polypropylene stress plate.	3" round	SFS Group USA, Inc.
9.	Dekfast PLT-R-2-4B	2" round galvalume AZ50 steel plate.	2" round	SFS Group USA, Inc.
10.	ASAP RoofGrip Pre-Assembled System	Pre-assembled Roofgrip #12, #14, #15, OMG Heavy Duty and XHD fasteners with approved plates.	Various	OMG, Inc.
11.	Recessed Metal Plate	Galvalume stress plate	3" square	OMG, Inc.
12.	Maxload Fastener	Insulation fastener for wood, steel and concrete decks.	Various	OMG, Inc.
13.	OMG 2" Barbed Plate	Round galvanized steel stress plate.	2" round	OMG, Inc.
14.	OMG Heavy Duty	Insulation fastener for wood, steel and concrete decks.	Various	OMG, Inc.



**APPROVED FASTENERS / ADHESIVES:**

**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
15.	OMG 3” Galvalume Steel Plate	Galvalume round stress plate.	3” round	OMG, Inc.
16.	Trufast #15 EHD Fastener	Insulation fastener for wood, steel and concrete decks.	Various	Altenloh, Brinck & Co. U.S., Inc.
17.	Trufast 3” Metal Insulation Plate	Galvalume AZ50 steel plate.	3” diameter	Altenloh, Brinck & Co. U.S., Inc.
18.	Tremco #15 EHD Fastener	Insulation fastener for wood, steel and concrete decks.	Various	Tremco CPG Inc.
19.	Tremco 3” Metal Insulation Plate	Galvalume AZ50 steel plate.	3” diameter	Tremco CPG Inc.
20.	Trufast #14 HD Fastener	Insulation fastener for wood, steel and concrete decks.	Various	Altenloh, Brinck & Co. U.S., Inc.
21.	Tremco #14 HD Fastener	Insulation fastener for wood, steel and concrete decks.	Various	Tremco CPG Inc.
22.	3 in. Ribbed Galvalume Plate	Galvalume round stress plate.	3” round	OMG, Inc.
23.	Trufast Deep Well Coiled Batten Bar	Insulation batten bar.	1” x 100’ coil	Altenloh, Brinck & Co. U.S., Inc.
24.	Tremco Coil MB-R	Insulation batten bar.	1” x 100’ coil	Tremco CPG Inc.
25.	OMG XHD	Insulation fastener for wood and steel decks.	Various	OMG, Inc.
26.	Millennium One Step Foamable Adhesive	Polyurethane two component high rise insulation adhesive.	1.5 liters	H.B. Fuller Company
27.	Millennium PG-1 Low Viscosity Insulation Adhesive	Polyurethane two component low rise insulation adhesive.	1.5 liters	H.B. Fuller Company
28.	OMG OlyBond Adhesive	A two-component, cold-applied adhesive.	Various	OMG, Inc.
29.	OMG OlyBond 500	A two-component, cold-applied adhesive.	Various	OMG, Inc.



**APPROVED SURFACING / COATING OPTIONS:**

**TABLE 4**

**Chosen components must be applied according to manufacturer’s application instructions. Any coating, listed below, used as a surfacing, must be listed within a current NOA.**

<u>System Number</u>	<u>Manufacturer</u>	<u>Application</u>
1.	Tremco CPG Inc.	Flood coat of THERMastic 80 adhesive or hot roofing asphalt and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.
2.	Tremco CPG Inc.	Flood coat of BURmastic Adhesive (aka POWERply Standard Cold Adhesive) or Premium IV and gravel/slag with an application rate of 4.0-5.0 gal./sq., 48-72 lbs./sq., & 400 lbs./sq., respectively.
3.	Tremco CPG Inc.	Flood coat of Rock-It Adhesive and gravel/slag with an application rate of 5.0 gal./sq. & 200 lbs./sq., respectively.
4.	Tremco CPG Inc.	Flood coat of Rock-It Adhesive WB and gravel/slag with an application rate of 5.0 gal./sq. & 200 lbs./sq., respectively.
5.	Tremco CPG Inc.	TremLastic S adhesive with an application rate of 4.0-5.0 gal./sq.
6.	Tremco CPG Inc.	Alumanation 301 with an application rate of 2.0-2.5 gal./sq.
7.	Tremco CPG Inc.	ICE Coating with an application rate of 4.0-5.0 gal./sq.



**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Test Name</u>	<u>Date</u>
Factory Mutual Research Corporation	1994 FM	Current Insulation Fastening Requirements	01/01/94
	2Y9A5.AM	FM 4470	11/13/95
	1B0A5.AM	FM 4470	11/06/97
	2D1A8.AM	FM 4470	07/27/00
	0D0A9.AM	FM 4470	08/01/00
	3D8A7.AM	FM 4470	08/02/00
	3005298	FM 4470	05/10/02
	3018436	FM 4470	02/09/04
	3018437	FM 4470	02/09/04
	3015502	FM 4470	12/30/04
	3026215	FM 4470	05/19/06
	3033461	FM 4470	09/16/08
	3045534	FM 4470	04/04/12
	3042560	FM 4470	04/23/12
3040922	FM 4470	06/13/12	
PRI Asphalt Technologies, Inc.	TRE-061-02-01	ASTM D6163	10/04/12
	TRE-106-02-01	ASTM D2178	12/18/12
	TRE-107-02-01	ASTM D2178	12/18/12
	881T0008	ASTM D312	06/06/22
Underwriters Laboratories, Inc.	TGFU.R6692	Fire Classification Compliance	02/07/18
Trinity ERD	SC6775.12.14	FM 4474 / TAS 114	12/31/14
	SC9625.11.15-2-R1	FM 4474 / TAS 114	11/17/15
	11090.07.16-1	FM 4474 / TAS 114	07/18/16
	11090.10.16-1	FM 4474 / TAS 114	10/20/16
	12935.10.16	FM 4474 / TAS 114	10/20/16
	12530.10.16-2	FM 4474 / TAS 114	10/20/16
	11675.10.16	FM 4474 / TAS 114	10/20/16
	6775.11.16-6-1	FM 4474	11/16/16
	TRM-SC6910.12.16	Various Standards	12/22/16
	13625.04.17	FM 4474 / TAS 114	04/06/17
	13625.04.17-1	FM 4474 / UL 1897 / TAS 114	04/20/17
	13625.05.17-1	FM 4474 / UL 1897 / TAS 114	05/24/17
	NEMO ETC, LLC	13625.05.17-1	FM 4474 / TAS 114
13625.01.18-3A		FM 4474 / TAS 114	01/08/18
13625.01.18-3B		FM 4474 / TAS 114	01/08/18
13625.01.18-1		FM 4474 / UL 1897 / TAS 114	01/09/18
2-TRM-18-001.01.18-1B		FM 4474 / TAS 114	01/29/18
TRM-SC13455.11.17-1-R2		Various Standards	01/15/18
TRM-SC13455.11.17-2-R2		Various Standard	01/15/18
2-TRM-18-001.07.18-1A		FM 4474 / UL 1897 / TAS 114	07/16/18
2-TRM-18-001.07.18-2A		FM 4474 / UL 1897 / TAS 114	07/16/18
4i-TRM-19-SSCRT-03.A		TAS 117 (B) / ASTM D 1876	08/16/19
4q-TRM-19-SSMBB-01.B		ASTM D 6162	10/24/19
4q-TRM-19-SSMBB-01.C		ASTM D 6162	10/24/19





**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Test Name</u>	<u>Date</u>
	4q-TRM-19-SSMBB-01.D	ASTM D 6162	10/24/19
	4q-TRM-19-SSMBB-01.E	ASTM D 6163	10/24/19
	4q-TRM-19-SSMBB-01.F	ASTM D 6163	10/24/19
	4q-TRM-19-SSMBB-01.G	ASTM D 6164	10/24/19
	4q-TRM-19-SSMBB-01.H	ASTM D 6164	10/24/19
	4q-TRM-19-SSMBB-01.A	ASTM D 6162	02/07/20
	4i-TRM-19-SSCRT-04.A	ASTM D 903	03/10/20
	4a-TRM-20-LSWUS-04.A	FM 4474 / UL 1897 / TAS 114	11/25/20
	4a-TRM-21-LSWUS-01.A-R1	FM 4474 / TAS 114	06/15/21
	4q-TRM-21-SSMBB-02.A.R1	ASTM D 4601 / ASTM D 5147	12/16/21

**DECK STRESS ANALYSIS CALCULATIONS/REPORTS:**

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	Signed/Sealed Calculations	D(13)	01/29/18
		B(4), B(5), B(6), B(7), C(3), D(2), D(3), D(4), D(8), D(9), D(10)	09/26/19
		B(10), C(3), D(1), D(5), D(6), D(7), D(11), D(12), D(14)	See Uplift Test Reports
		A(1), A(2), A(3), C(7)	08/31/23
FM Approval Deck Limitations	N/A	B(1), B(2), B(3), B(8), B(9), C(1), C(2), C(4), C(5), C(6), C(8)	10/09/19



**APPROVED ASSEMBLIES:**

**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened 6” o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 20” o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**  
**System Type A(1):** One or more layers of insulation adhered with approved adhesive onto steel deck  
**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
MONOBOARD Minimum 1.0” thick	N/A	N/A

**Note:** All insulations shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4” – 1” wide ribbons, 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive at a rate of 2.5-3.0 gal./sq.  
**Ply Sheet:** BURmastic Composite Ply HT adhered with BURmastic Adhesive or POWERply Standard Cold Adhesive at a rate of 2.0-2.5 gal./sq.  
**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with BURmastic Adhesive or POWERply Standard Cold Adhesive at a rate of 2.0-2.5 gal./sq.  
**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.  
**Maximum Design Pressure:** -52.5 psf (See General Limitation #9.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**  
**System Type A(2):** One or more layers of insulation adhered with approved adhesive onto steel deck  
**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
TOPROCK DD Minimum 2.0" thick	N/A	N/A

**Note: All insulations shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4" – 1" wide ribbons, 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive at a rate of 2.5-3.0 gal./sq.  
**Ply Sheet: (Optional)** BURmastic Composite Ply HT adhered with BURmastic Adhesive or POWERply Standard Cold Adhesive at a rate of 2.0-2.5 gal./sq.  
**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with BURmastic Adhesive or POWERply Standard Cold Adhesive at a rate of 2.0-2.5 gal./sq.  
**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.  
**Maximum Design Pressure:** -60.0 psf (See General Limitation #9.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**

**System Type A(3):** One or more layers of insulation adhered with approved adhesive onto steel deck

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck, DensDeck Prime, DEXcell FA Glass Mat Roof Board Minimum 1/4" thick	N/A	N/A

**Note: All insulations shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4" – 1" wide ribbons, 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Ply Sheet: (Optional)** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq. or BURmastic Adhesive SF at a rate of 2.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -82.5 psf (See General Limitation #9.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 33 steel deck fastened 6” o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24” o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**  
**System Type B(1):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0” thick	1, 15	1:1.6 ft <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating Minimum ½” thick	N/A	N/A

**Note:** Top layer of insulation shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous ¾” wide ribbons, 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 25-30 lbs/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or



POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
Or  
POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -45 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**  
**System Type B(2):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	1, 15	1:1.6 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating Minimum 1/2" thick	N/A	N/A

**Note: Top layer of insulation shall be adhered with FAS-N-FEE in continuous 3/4" wide ribbons, 6" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 25-30 lbs/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 25-30 lbs/sq.



**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -45 psf (See General Limitation #7.)





**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with Traxx/5 fasteners into steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with Traxx/1 fasteners spaced max. 30" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table**  
**System Type B(3):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	4, 5	1:2 ft <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating Minimum 1/2" thick	N/A	N/A

**Note:** Apply top layer of insulation in a full mopping of approved hot asphalt applied within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or in FAS-N-FREE adhesive applied in 1/2" to 3/4" wide ribbons at a coverage rate of 1.5 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side face down.

**Base Sheet:** BURmastic Composite Ply HT, or BURmastic Glass Ply adhered with THERMastic 80 or Premium IV asphalt.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 or Premium IV asphalt.

**Ply Sheet:** THERMglass Type IV or THERMglass Premium VI sheet adhered with THERMastic 80 or Premium IV asphalt.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 or Premium IV asphalt.



**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-60 psf. (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened with 3/4" steel washers 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 5 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type B(4):** Base layer of insulation mechanically fastened, additional insulation layer(s) and top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	16, 17, 18, 19	1:2 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Additional Insulation Layer(s)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating, DensDeck Prime, DEXcell FA Glass Mat Roof Board, SECUROCK Gypsum-Fiber Roof Board, SECUROCK Cement Roof Board Minimum 1/2" thick	N/A	N/A

**Note: Top insulation layer shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4" wide ribbons, 6" o.c. and 12" o.c. for additional insulation layer(s). Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with BURmastic Adhesive SF at a rate of 2.0 gal./sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive SF at a rate of 2.0 gal./sq.



**Ply Sheet:  
(Optional)** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq.

Or

POWERply Heavy Duty Base Sheet adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -60 psf (See General Limitation #7.)



- Membrane Type:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened with 3/4" steel washers 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 5 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**
- System Type B(5):** Base layer of insulation mechanically fastened, additional insulation layer(s) and top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	16, 17, 18, 19	1:2 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Additional Insulation layer(s)</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating Minimum 1/2" thick	N/A	N/A

**Note: Top insulation layer shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4" wide ribbons, 6" o.c. and 12" o.c. for additional insulation layer(s). Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

- Base Sheet:** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs/sq.
- Or
- THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 25-30 lbs/sq.
- Or



POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Ply Sheet:**

None

**Cap Sheet:**

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq.

**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-60.0 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened with 3/4" steel washers 6" o.c. with ITW Buildex Traxx/5 fasteners along each steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type B(6):** Thermal barrier mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Thermal Barrier</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime, DEXcell FA Glass Mat Roof Board Minimum 1/2" thick	6 (#14), 7, 19, 20, 21	1:2 ft <sup>2</sup>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick	19, 20, 21	1:2 ft <sup>2</sup>
SECUROCK Gypsum-Fiber Roof Board Minimum 5/8" thick	6 (#14), 7	1:2 ft <sup>2</sup>

**Note: Thermal barrier shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

**Vapor Barrier:** BURmastic Composite Ply HT or POWERply Heavy Duty Base applied in POWERply Endure BIO Adhesive to the thermal barrier at full-coverage at a rate of 2.0 gal./sq.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G, ACFoam-III, ISO 95+ GL, RESISTA, EnergyGuard Polyiso Insulation, H-Shield, ENRGY 3, Multi-Max FA-3, Ultra-Max Minimum 1.0" thick	N/A	N/A



**Top Insulation Layer**

**Insulation Fasteners**

**Fastener Density/ft<sup>2</sup>**

**(Table 3)**

<b>DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, SECUROCK Cement Roof Board, DEXcell FA Glass Mat Roof Board Minimum ½” thick</b>	<b>N/A</b>	<b>N/A</b>
---	------------	------------

**Note: Layers of insulation shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous ¾” to 1” wide ribbons, 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** POWERply Standard Smooth HW, torch-applied.

**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR HW, torch-applied.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -67.5 psf (See General Limitation #7.)





**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type B(7):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	17, 19, 20, 21	1:2 ft <sup>2</sup>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
Structodek HD with Primed Red Coating Minimum 1/2" thick	N/A	N/A

**Note:** Top layer of insulation shall be adhered with Hot asphalt at a rate of 20-40 lbs/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Glass Ply adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with THERMastic 80 at 25-30 lbs/sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at 20-40 lbs/sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 25-30 lbs/sq.



**Ply Sheet:** None.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -67.5 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type B(8):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	1, 15	1:1.45 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Minimum 1/4" thick	N/A	N/A

**Note: Top layer of insulation shall be adhered with Hot asphalt at a rate of 20-40 lbs./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs./sq.  
 Or  
 POWERply Heavy Duty Base Sheet adhered with Hot asphalt at a rate of 20-40 lbs./sq.  
 Or  
 BURmastic Composite Ply HT adhered with BURmastic Adhesive SF at a rate of 2.0 gal./sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive SF at a rate of 2.0 gal./sq.

**Ply Sheet:** None



**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs./sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -75 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type B(9):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	1, 15	1:1.45 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Minimum 1/4" thick	N/A	N/A

**Note: Top layer of insulation shall be adhered with Hot asphalt at a rate of 20-40 lbs./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs./sq.  
 Or  
 BURmastic Glass Ply or BURmastic Composite Ply HT adhered with THERMastic 80 at 25-30 lbs/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs./sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 25-30 lbs/sq.



**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs./sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -75 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type B(10):** Base layer of insulation mechanically fastened, top insulation layer adhered with approved adhesive. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	22, 25	1:1 ft <sup>2</sup>

**Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).**

<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Minimum 1/2" thick	N/A	N/A

**Note: Top layer of insulation shall be adhered with Tremco Low Rise Foam Insulation Adhesive, Tremco Low Rise Foam Insulation Adhesive (BG), Tremco LR Adhesive, Tremco LR Adhesive (BG), Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive in continuous 3/4" – 1" wide ribbons, 6" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Composite Ply HT adhered with BURmastic Adhesive MC or BURmastic Adhesive at a rate of 2 gal./sq.

Or

POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive MC at a rate of 2 gal./sq.

Or

POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive at a rate of 2 gal./sq.

**Ply Sheet:** BURmastic Composite Ply HT adhered with BURmastic Adhesive MC or BURmastic Adhesive at a rate of 2 gal./sq.

Or



POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive MC at a rate of 2 gal./sq.

Or

POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive at a rate of 2 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with BURmastic Adhesive at a rate of 2 gal./sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:** -97.5 psf (See General Limitation #7.)





**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to ¼" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(1):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Minimum ½" thick	1, 15	1:1.6 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Composite Ply HT adhered with BURmastic Adhesive SF at a rate of 2.0 gal/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with BURmastic Adhesive SF at a rate of 2.0 gal/sq.

**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal/sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with BURmastic Adhesive SF at a rate of 2.0 gal/sq.



**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-60 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to ¼" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 30" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type C(2):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime Minimum ½" thick	1, 15	1:1.6 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with THERMastic 80 at 25-30 lbs/sq.  
 Or  
 POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs./sq.  
 Or  
 POWERply Heavy Duty Base Sheet adhered with THERMastic 80 at a rate of 25-30 lbs/sq.

**Ply Sheet:** None

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR, POWERply Endure 320 FR or POWERply HE FR Plus adhered with Hot asphalt at a rate of 20-40 lbs./sq.



**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-60 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 at 5 ft. spans attached 6" o.c. with 5/8" diameter puddle welds. Side laps attached with Tek/1 screws spaced 12" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type C(3):** All layers of insulation simultaneously mechanically fastened

**All General and System Limitations apply.**

One or more layers of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.5" thick	N/A	N/A

**Note: Both layers of insulation shall be simultaneously mechanically fastened: see top layer below for fasteners and density.**

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
MONOBOARD PLUS Minimum 1.0" thick	16, 18, 23, 24	1:1.5 ft <sup>2</sup> (12" o.c. through bars spaced 18" o.c.)

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** POWERply Standard Smooth HW, torch-applied.  
**Ply Sheet:** None.  
**Cap Sheet:** POWERply Standard FR HW, torch-applied.  
**Surfacing:** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.  
**Maximum Design Pressure:** -67.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

- Deck Description:**
1. 18 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 72" o.c.
  2. 20 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 69" o.c.
  3. 22 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 62" o.c.
  4. Min. 18-22 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 72" o.c.

All of the above steel deck options are attached to structural supports with ITW Buildex Traxx/5 fasteners and 3/4" steel washers spaced 6" o.c. at each corrugation.

All of the above steel deck options; panel side laps are fastened 12" o.c. with ITW Buildex Traxx/1 fasteners.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(4):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G, ENRGY 3, Ultra-Max Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick	17, 19, 20, 21	1:1.33 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** THERMglass Type IV or THERMglass Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs/sq.



Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Ply Sheet:**

THERMglass Type IV or THERMglas Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Cap Sheet:**

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-112.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

- Deck Description:**
1. 18 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 68" o.c.
  2. 20 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 58" o.c.
  3. 22 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 52" o.c.
  4. Min. 18-20 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 72" o.c.
  5. Min. 22 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 71" o.c.

All of the above steel deck options are attached to structural supports with ITW Buildex Traxx/5 fasteners and 3/4" steel washers spaced 6" o.c. at each corrugation.

All of the above steel deck options; panel side laps are fastened 12" o.c. with ITW Buildex Traxx/1 fasteners.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(5):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G, ENRGY 3, Ultra-Max Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick	17, 19, 20, 21	1:1 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** THERMglass Type IV or THERMglass Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
Or  
THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.  
Or





POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Ply Sheet:**

THERMglass Type IV or THERMglas Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Cap Sheet:**

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

- Deck Description:**
1. 18 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 68" o.c.
  2. 20 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 58" o.c.
  3. 22 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 52" o.c.
  4. Min. 18-20 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 72" o.c.
  5. Min. 22 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 71" o.c.

All of the above steel deck options are attached to structural supports with ITW Buildex Traxx/5 fasteners and 3/4" steel washers spaced 6" o.c. at each corrugation.

All of the above steel deck options; panel side laps are fastened 12" o.c. with ITW Buildex Traxx/1 fasteners.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(6):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G, ENRGY 3, Ultra-Max Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick	17, 19, 20, 21	1:1.33 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs./sq.

Or

BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with THERMastic 80 at a rate of 20-40 lbs./sq.

Or



POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs./sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth with THERMastic 80 at a rate of 20-40 lbs./sq.

**Ply Sheet:**

THERMglass Type IV or THERMglas Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Cap Sheet:**

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 18-22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to ¼" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(7):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ENRGY 3 Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
SECUROCK Gypsum-Fiber Roof Board Minimum ½" thick	16, 17, 18, 19	1:1.0 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Ply Sheet: (Optional)** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Standard Cold Adhesive or BURmastic Adhesive at a rate of 1.5-2.0 gal./sq. or BURmastic Adhesive SF at a rate of 2.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -165.0 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

- Deck Description:**
1. 18 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 65" o.c.
  2. 20 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 56" o.c.
  3. 22 ga., Type B, Grade 33 steel deck attached to supports having a maximum span of 50" o.c.
  4. Min. 18-20 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 72" o.c.
  5. Min. 22 ga., Type B, Grade 80 steel deck attached to supports having a maximum span of 68" o.c.

All of the above steel deck options are attached to structural supports with ITW Buildex Traxx/5 fasteners and 3/4" steel washers spaced 6" o.c. at each corrugation.

All of the above steel deck options; panel side laps are fastened 12" o.c. with ITW Buildex Traxx/1 fasteners.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type C(8):** All layers of insulation simultaneously attached. Membranes subsequently adhered to insulation.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G, ENRGY 3, Ultra-Max Minimum 1.5" thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick	17, 19, 20, 21	1:1 ft <sup>2</sup>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with Hot asphalt at a rate of 20-40 lbs./sq.

Or

BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with THERMastic 80 at a rate of 20-40 lbs./sq.

Or



POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth adhered with Hot asphalt at a rate of 20-40 lbs./sq.

Or

POWERply Heavy Duty Base Sheet, POWERply Endure 100 Smooth, POWERply Endure 200 Smooth, POWERply Endure 300 Smooth or POWERply Endure 320 Smooth with THERMastic 80 at a rate of 20-40 lbs./sq.

**Ply Sheet:**

THERMglass Type IV or THERMglas Premium VI adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

THERMglass Type IV or THERMglass Premium VI adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Cap Sheet:**

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.

Or

POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-172.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 18-22 ga., Type B, Grade 80 at 4.5' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 12" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(1):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Endure 200 Smooth, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates, Tremco 2.4" Barbed Seam Plates or Trufast 2" Barbed Seam Plates, Tremco 2" Barbed Seam Plates at 6" o.c. within every-third 5" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 75 lineal feet per gallon. The 3" wide laps between fastened laps sealed with POWERply Endure BIO Adhesive at 2 gal./sq.

**Ply Sheet:** None.

**Cap Sheet:** POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -82.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(2):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 12" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet: (Optional)** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Heavy Duty Base adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -90 psf (See General Limitation #7.)





**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(3):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 12" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet: (Optional)** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.

Or

POWERply Heavy Duty Base Sheet adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.



**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

-90 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**  
**System Type D(4):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:  
**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 12" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.  
**Ply Sheet:** POWERply Standard Smooth HW, torch-applied.  
**(Optional)**  
**Cap Sheet:** POWERply Standard FR HW, torch-applied.  
**Surfacing:** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or  
**(Optional)** required fire classification.  
**Maximum Design Pressure:** -90 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(5):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
EnergyGuard Polyiso Insulation Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Endure 200 Smooth, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates, Tremco 2.4" Barbed Seam Plates or Trufast 2" Barbed Seam Plates, Tremco 2" Barbed Seam Plates at 6" o.c. within the 5" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 75 lineal feet per gallon.

**Ply Sheet:** None.

**Cap Sheet:** POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -97.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(6):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. within the 5" side lap. Side laps are sealed with POWERply Endure BIO Adhesive TF at 75 lineal feet per gallon.

**Ply Sheet (Optional):** BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR, and POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive TF at a rate of 2.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -105.0 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with ITW Buildex Traxx/5 fasteners attached to 1/4" steel structural supports spaced maximum 6 ft. o.c. Deck side laps are attached with ITW Buildex Traxx/1 fasteners spaced max. 24" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(7):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** BURmastic Composite Ply HT, mechanically attached as detailed below:

**Fastening:** OMG XHD fasteners with 3 in. Ribbed Galvalume Plates at 6" o.c. at minimum 4" wide side laps and 6" o.c. at two equally spaced center rows.

**Ply Sheet:** BURmastic Glass Ply adhered with BURmastic Adhesive MC or BURmastic Adhesive at a rate of 2 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with BURmastic Adhesive at a rate of 2 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -120.0 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 or Grade 80 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table. See Maximum Design Pressures for each Grade of steel.**

**System Type D(8):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet: (Optional)** BURmastic Glass Ply or BURmastic Composite Ply HT adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Standard FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Endure BIO Adhesive at a rate of 2.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** Grade 40 steel: -103.3 psf (See General Limitation #7.)  
 Grade 80 steel: -157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** Min. 22 ga., Type B, Grade 40 or Grade 80 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table. See Maximum Design Pressures for each Grade of steel.**  
**System Type D(9):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet: (Optional)** BURmastic Glass Ply, THERMglass Type IV, THERMglass Premium VI or BURmastic Composite Ply HT adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.

Or

POWERply Standard FR adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with approved mopping of asphalt applied with the EVT range at an application rate of 20-40 lbs./sq., or adhered with THERMastic 80 at a rate of 25-30 lbs./sq.





**Surfacing:  
(Optional)**

Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design  
Pressure:**

Grade 40 steel: -103.3 psf (See General Limitation #7.)  
Grade 80 steel: -157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 40 or Grade 80 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table. See Maximum Design Pressures for each Grade of steel.**

**System Type D(10):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. at the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet:** POWERply Standard Smooth HW, torch-applied.  
**(Optional)**

**Cap Sheet:** POWERply Standard FR HW, torch-applied.

**Surfacing:** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or  
**(Optional)** required fire classification.

**Maximum Design Pressure:** Grade 40 steel: -103.3 psf (See General Limitation #7.)  
Grade 80 steel: -157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 20" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(11):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Endure 200 Smooth, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast Deep Well Coiled Batten Bar or Tremco Coil MB-R Batten Bar at 6" o.c. within the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 75 lineal feet per gallon.

**Ply Sheet:** None.

**Cap Sheet:** POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -120.0 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 at 6' spans attached 6" o.c. with two (2) Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 12" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(12):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 2.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. within the 4" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 75 lineal feet per gallon.

**Ply Sheet:** None.

**Cap Sheet:** POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2.0 gal./sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with Hot asphalt at a rate of 20-40 lbs/sq.  
 Or  
 POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with THERMastic 80 at a rate of 20-40 lbs/sq.

**Surfacing:  
(Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -157.5 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 at 6' spans attached 6" o.c. with Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 12" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(13):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
H-Shield Minimum 2.0" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. at the 5" side lap and 6" o.c. at one spaced center row. Side laps are sealed with POWERply Endure BIO Adhesive at 60 lineal feet per gallon.

**Ply Sheet: (Optional)** POWERply Heavy Duty Base Sheet adhered with POWERply Endure BIO Adhesive at a rate of 2 gal./sq.  
 Or  
 POWERply Standard Smooth HW, torch-applied.

**Cap Sheet:** POWERply Standard FR, POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 2 gal./sq.  
 Or  
 POWERply Standard FR HW, torch-applied.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -206.7 psf (See General Limitation #7.)



**Membrane Type:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 at 6' spans attached 6" o.c. with two (2) Tek/5 screws and 3/4" diameter washers. Side laps with Tek/1 screws, 12" o.c.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**System Type D(14):** All layers of insulation and base sheet simultaneously attached. Membranes subsequently adhered to base sheet.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ACFoam-II, Trisotech G Minimum 1.5" thick	N/A	N/A

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Base Sheet:** POWERply Heavy Duty Base Sheet, mechanically attached as detailed below:

**Fastening:** Trufast #15 EHD Fasteners, Tremco #15 EHD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Tremco 2.4" Barbed Seam Plates at 6" o.c. within the 5" side lap. Side laps are sealed with POWERply Endure BIO Adhesive at 75 lineal feet per gallon and 6" o.c. in one center row.

**Ply Sheet:** None.

**Cap Sheet:** POWERply Endure 100 FR, POWERply Endure 200 FR, POWERply Endure 300 FR or POWERply Endure 320 FR adhered with POWERply Endure BIO Adhesive at a rate of 3.0 gal./sq.

**Surfacing: (Optional)** Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

**Maximum Design Pressure:** -247.5 psf (See General Limitation #7.)



## STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 22-0726.01  
Expiration Date: 07/12/26  
Approval Date: 06/13/24  
Page 63 of 63