

# DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

# MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/pera

#### **NOTICE OF ACCEPTANCE (NOA)**

Ceramic Group International LLC. 127 Yacht Club Way Apt. 110 Hypoluxo, FL. 33462

#### **SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

#### **DESCRIPTION:** Milano "S" Clay Roof Tile

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Alex Tigera.

MIAMI-DADE COUNTY
APPROVED

06/27/24

NOA No.: 24-0227.03 Expiration Date: 06/27/29 Approval Date: 06/27/24

Page 1 of 5

#### ROOFING ASSEMBLY APPROVAL

<u>Category:</u> Roofing

<u>Sub Category:</u> Roofing Tiles

Material: Clay

#### 1. SCOPE

This approves a roofing system using Milano "S" Clay Roof Tiles manufactured by Klass LLC in Baku, Azerbaijan and is distributed by Ceramic Group International LLC., as described in Section 2 of this Notice of Acceptance. For locations where the pressure requirements, as determined by applicable Building Code does not exceed the design pressure values obtained by calculations in compliance with RAS 127 using the values listed in section 4 herein. The attachment calculations shall be done as a moment based system.

#### 2. PRODUCT DESCRIPTION

Manufactured by Applicant	Dimensions	Test Specifications	Product Description
Milano "S" Clay Roof Tile	L = 16.1" W = 10.3" 0.48" thick nominal 2.3" high	ASTM C 1167 Type – II Grade - 1	"S" profile clay roof tile. For direct deck adhesive set applications with the nominal interlocking headlap.
Trim Pieces	Length: varies Width: varies varying thickness	ASTM C 1167	Accessory trim, clay roof pieces for use at hips, rakes, ridges and valley terminations manufactured for each tile profile.

#### 2.1 PRODUCTS MANUFACTURED BY OTHERS

<u>Product Name</u>	<b>Product Description</b>	<u>Manufacturer</u> (With Current NOA)
ICP Adhesives Polyset AH-160	Two component polyurethane foam adhesive.	ICP Construction, Inc.

#### 2.2 MANUFACTURING LOCATION

2.1.1. Baku, Azerbaijan

#### 2.3 EVIDENCE SUBMITTED

<b>Test Agency</b>	<b>Test Identifier</b>	<b>Test Name/Report</b>	<u>Date</u>
American Test Lab of South	RT0917.04-23	ASTM C 1167	11/08/23
Florida	RT0917.05-23	TAS 101	11/08/23



NOA No.: 24-0227.03 Expiration Date: 06/27/29 Approval Date: 06/27/24

Page 2 of 5

#### 3. **LIMITATIONS:**

- **3.1** Fire classification is not part of this acceptance.
- 3.2 For mortar or adhesive set tile applications, a static field uplift test in accordance with TAS 106 may required, refer to applicable building code.
- Applicant shall retain the services of a Miami-Dade County Certified Laboratory to perform quarterly test in 3.3 accordance with TAS 112, appendix 'A'. Such testing shall be submitted to the Regulatory and Economic Development Department – Product Control Section for review.
- 3.4 Minimum underlayment shall be in compliance with the applicable Roofing Applications Standards listed section 4.1 herein.
- 30/90 hot mopped underlayment applications may be installed perpendicular to the roof slope unless stated otherwise by the underlayment material manufacturers published literature.
- 3.6 This acceptance is for wood deck applications. Minimum deck requirements shall be in compliance with applicable building code.

#### 4. INSTALLATION

- **4.1** Milano "S" Clay Roof Tile and its components shall be installed in strict compliance with Roofing Application Standard RAS-120.
- **4.2** Data For Attachment Calculations.

Table 1: Average Weight (W) and Dimensions (I x w )			
Tile Profile	Weight-W (lbf)	Length-I (ft)	Width-w (ft)
Milano "S" Clay Roof Tile	6.6	1.34	0.86

Table 2: Aerodynamic Multipliers - λ (ft³)			
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$			
Milano "S" Clay Roof Tile	N/A	0.21	

Table 3: Restoring Moments due to Gravity - Mg (ft-lbf)						
Tile Profile	2":12"	3":12"	4":12"	5":12"	6":12"	7":12" or Greater
Milano "S"	Direct Deck					
Clay Roof Tile	4.91	4.85	4.76	4.65	4.53	4.39

Table 6: Attachment Resistance Expressed as a Moment - M <sub>f</sub> (ft-lbf) for Single Patty Adhesive <sup>1</sup> Set Systems			
Tile Profile	Tile Application	Minimum Attachment Resistance	
Milano "S" Clay Roof Tile	ICP Adhesives Polyset AH-160	82.42	

See manufactures component approval for installation requirements.

Large paddy placement weight 28.6 grams of ICP Adhesives Polyset AH-160



NOA No.: 24-0227.03 **Expiration Date: 06/27/29** Approval Date: 06/27/24

Page 3 of 5

#### 5. LABELING

5.1 All tiles shall bear the imprint or identifiable marking of the manufacturer's name or logo as detailed below, or following statement: "Miami-Dade County Product Control Approved".

# SULTAN KERAMIK Milano Made in Azerbaijan

LABEL FOR MILANO "S" CLAY ROOF TILE (LOCATED ON THE SIDE OF TILE)

### 6. BUILDING PERMIT REQUIREMENTS:


- **6.1** Application for building permit shall be accompanied by copies of the following:
  - **6.1.1** This Notice of Acceptance.
  - **6.1.2** Any other documents required by Building Official or Applicable building code in order to properly evaluate the installation of this system.



NOA No.: 24-0227.03 Expiration Date: 06/27/29 Approval Date: 06/27/24

Page 4 of 5

## PROFILE DRAWING



(DIMENSIONS SHOWN ARE IN MILLIMETERS)

# MILANO "S" CLAY ROOF TILE **END OF THIS ACCEPTANCE**



NOA No.: 24-0227.03 **Expiration Date: 06/27/29** Approval Date: 06/27/24

Page 5 of 5