



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**GAF**  
**1 Campus Drive**  
**Parsippany, NJ 07054**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: GAF EverGuard® TPO Single Ply Roofing Systems over Lightweight Concrete Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No.19-0807.03 and consists of pages 1 through 29.

The submitted documentation was reviewed by Jorge L. Acebo.

07/25/24



NOA No.: 24-0322.09  
Expiration Date: 04/16/29  
Approval Date: 07/25/24  
Page 1 of 29

## ROOFING SYSTEM APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Single Ply Roofing
<b>Material:</b>	TPO
<b>Deck Type:</b>	Lightweight Concrete
<b>Maximum Design Pressure:</b>	-300 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

**TABLE 1**

<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
EverGuard® TPO	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced single-ply membrane.
EverGuard Extreme® TPO	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced single-ply membrane designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Fleece-Back	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced, fleece back single-ply membrane
EverGuard Extreme® TPO Fleece-Back	Various	ASTM D6878 TAS 131	Thermoplastic olefin reinforced fleece back single-ply membrane designed for advanced protection against heat aging and UV degradation.
GAFGLAS® Ply 4	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
Tri-Ply® Ply 4	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
GAFGLAS® FlexPly™ 6	39.37" (1 meter) Wide	ASTM D2178	A smooth surfaced asphaltic ply sheet reinforced with fiberglass mat.
GAFGLAS® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D4601	A smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
Tri-Ply® #75 Base Sheet	39.37" (1 meter) Wide	ASTM D4601	A smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
GAFGLAS® #80 Ultima™ Base Sheet	39.37" (1 meter) Wide	ASTM D4601	A smooth asphaltic base or base/ply sheet reinforced with fiberglass mat.
Ruberoid® 20 Smooth	39.37" (1 meter) Wide	ASTM D6163	A SBS polymer-modified asphalt base or ply sheet reinforced with a fiberglass mat.
Ruberoid® Mop Smooth 1.5	39.37" (1 meter) Wide	ASTM D6164	Smooth surfaced mop applied SBS base or ply sheet reinforced with a polyester mat.
GAFGLAS® Stratavent® Nailable Venting Base Sheet	39.37" (1 meter) Wide	ASTM D4897	A nailable, fiberglass base sheet coated on both sides with asphalt. Surfaced on the bottom side with mineral granules embedded in asphaltic coating.



<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
Ruberoid® HW Smooth	39.37" (1 meter) wide	ASTM D6164	Smooth surfaced torch applied SBS base or ply sheet reinforced with a polyester mat.
Ruberoid® HW 25 Smooth	39.37" (1 meter) wide	ASTM D6163	Smooth surfaced torch applied SBS base or ply sheet reinforced with a fiberglass mat.
Matrix™ 307 Premium Asphalt Primer	1, 5 or 55 Gallons	ASTM D41	Asphalt concrete primer used to promote adhesion of all types of asphalt-based roofing materials.
EverGuard® WB181 Bonding Adhesive	5 Gallons	Proprietary	A water based adhesive for TPO based membranes.
EverGuard® TPO 1121 Bonding Adhesive	5 Gallons	Proprietary	Solvent based adhesive for fully adhered TPO systems and membrane flashing.
EverGuard® Quick Spray Adhesive LV50	36.3 lbs	Proprietary	Sprayable Low-VOC solvent based adhesive for fully adhered TPO systems and membrane flashing.
LRF Adhesive M	1:1 Applicator	Proprietary	A dual component foamable adhesive.
LRF Adhesive O	1:1 Applicator	Proprietary	A dual component polyurethane adhesive used to adhere single ply roof covers.
EverGuard® TPO Coated Metal	4' x 10' sheets	Proprietary	24 gauge steel with a 25 mil thick GAF TPO for edge detailing.
EverGuard Extreme® TPO Coated Metal	4' x 10' sheets	Proprietary	24 gauge steel with a 25 mil thick GAF TPO for edge detailing and designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Cover Tape	6" x 100' 10" x 100'	Proprietary	GAF TPO laminated to white butyl tape primarily used for edge metal details.
EverGuard® TPO Cover Tape Heat-Weld	6" x 100'	Proprietary	Flashing strip manufactured from unreinforced GAF TPO laminated to a six inch wide strip, half the strip with a self-adhered side and half the strip with a heat-weldable edge; used for edge metal details.
EverGuard Extreme® TPO Cover Tape Heat-Weld	6" x 100'	Proprietary	Flashing strip manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation. Laminated to a six inch wide strip, half the strip with a self-adhered side and half the strip with a heat-weldable edge; used for edge metal details.
EverGuard® TPO Detailing Membrane	24" x 50'	Proprietary	Unreinforced flashing material manufactured from GAF TPO.



<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
EverGuard Extreme® TPO Detailing Membrane	24" x 50'	Proprietary	Unreinforced flashing material manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Flashing Strip	Various	Proprietary	Reinforced flashing membrane manufactured from GAF TPO.
EverGuard Extreme® TPO Flashing Strip	Various	Proprietary	Reinforced flashing membrane manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Pourable Sealer Pocket	9" X 6" X 4" Oval With 3" Base Flange	Proprietary	Pourable sealer pocket is molded with GAF TPO compound to a nominal 70 mil thickness designed for waterproofing irregular shaped roof penetrations.
EverGuard Extreme® TPO Pourable Sealer Pocket	9" X 6" X 4" Oval With 3" Base Flange	Proprietary	Pourable sealer pocket is molded from GAF TPO designed for advanced protection against heat aging and UV degradation compounded to a nominal 70 mil thickness designed for waterproofing irregular shaped roof penetrations.
EverGuard® TPO Pourable Sealer Pocket	25" X 19" X 2" Oval With 2" Base Flange	Proprietary	Pourable sealer pocket is molded with GAF TPO compound to a nominal 55 mil thickness with a 2-piece split designed for waterproofing irregular shaped roof penetrations.
EverGuard Extreme® TPO Pourable Sealer Pocket	25" X 19" X 2" Oval With 2" Base Flange	Proprietary	Pourable sealer pocket is molded with GAF TPO compound to a nominal 55 mil thickness with a 2-piece split designed for waterproofing irregular shaped roof penetrations.
EverGuard® TPO RTA (Roof Transition Anchor) Strip™	6" x 100' Roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard Extreme® TPO RTA (Roof Transition Anchor) Strip™	6" x 100' Roll	Proprietary	Reinforced GAF TPO membrane with pressure sensitive adhesive primarily used to secure membrane transitions from the field to vertical surfaces.
EverGuard® TPO Split Pipe Boot	1" - 2" 3" - 5" 6" - 8"	Proprietary	Reinforced GAF TPO membrane split to accommodate most common pipes and conduits.



<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
EverGuard Extreme® TPO Split Pipe Boot	1" - 2" 3" - 5" 6" - 8"	Proprietary	Reinforced GAF TPO designed for advanced protection against heat aging and UV degradation split to accommodate most common pipes and conduits.
EverGuard® TPO Square Tube Wrap	4" x 4" 4" x 6" 6" x 6"	Proprietary	Reinforced GAF TPO with split design overlap to be wrapped around square or rectangular tubing.
EverGuard Extreme® TPO Square Tube Wrap	4" x 4" 4" x 6" 6" x 6"	Proprietary	Reinforced GAF TPO designed for advanced protection against heat aging and UV degradation with split design overlap to be wrapped around square or rectangular tubing.
EverGuard® TPO Corner Curb Wrap	Various	Proprietary	Corners fabricated from reinforced GAF TPO.
EverGuard Extreme® TPO Corner Curb Wrap	Various	Proprietary	Corners fabricated from reinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Scupper	4" x 6" x 12" 8" x 10" x 12"	Proprietary	Scupper manufactured from coated metal and unreinforced GAF TPO.
EverGuard® TPO T-Joint Cover Patch	100 Patches Per Box	Proprietary	T-Joint patch manufactured from unreinforced GAF TPO.
EverGuard Extreme® TPO T-Joint Cover Patch	100 Patches Per Box	Proprietary	T- Joint patch manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Vent	2 Vents Per Carton	Proprietary	Vent manufactured from reinforced GAF TPO membrane and galvanized steel.
EverGuard® TPO T-Top Vent	4" or 6"	Proprietary	Vent manufactured from reinforced GAF TPO membrane and galvanized steel.
EverGuard® TPO Walkway Rolls	Rolls 1/8" x 30" x 50'	Proprietary	Standard duty TPO walkway rolls.
EverGuard® TPO Inside Corner	6" x 6" x 5/4"	Proprietary	Inside corner manufactured from unreinforced GAF TPO.
EverGuard Extreme® TPO Inside Corner	6" x 6" x 5/4"	Proprietary	Inside corner manufactured from unreinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Universal Corners	Various	Proprietary	Universal corners manufactured from GAF TPO that are heat seamable and designed to accommodate both inside and outside corners of base and curb flashings manufactured from GAF TPO.



<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
EverGuard Extreme® TPO Universal Corners	Various	Proprietary	Universal corners manufactured from GAF TPO that are heat seamable and designed to accommodate both inside and outside corners of base and curb flashings manufactured from GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® TPO Vent Boot	1" - 6" o.d. 6 pcs. Crtn.	Proprietary	Vent pipe boot molded from GAF TPO and supplied with stainless steel clamping rings.
EverGuard Extreme® TPO Vent Boot	1" - 6" o.d. 6 pcs. Crtn.	Proprietary	Vent pipe boot molded from GAF TPO designed for advanced protection against heat aging and UV degradation and supplied with stainless steel clamping rings.
EverGuard® TPO Expansion Joint Cover	Various	Proprietary	Low profile joint cover manufactured from reinforced GAF TPO.
EverGuard® TPO Cut Edge Sealant	1 Quart Squeeze Tube	Proprietary	Clear solvent based sealant for TPO cut edges.
EverGuard® TPO Drain	Various	Proprietary	Spun aluminum drain pre-flashed with non-reinforced GAF TPO.
EverGuard® TPO Seam Cleaner	1 Gallon	Proprietary	Solvent based seam cleaner.
EverGuard® TPO Primer	1 gallon	Proprietary	Solvent based TPO primer.
EverGuard® Low VOC TPO Primer	1 gallon	Proprietary	Low VOC, solvent based TPO primer.
EverGuard® CleanWeld™ Conditioner	1 gallon	Proprietary	Low VOC cleaner for TPO.
EverGuard® TPO Fluted Corner	8" Diameter Nominal .05" Non-Reinforced	Proprietary	Flashing for outside corners of base and curb flashing manufactured from non-reinforced GAF TPO.
EverGuard® Extreme® TPO Fluted Corner	8" Diameter Nominal .05" Non-Reinforced	Proprietary	Flashing for outside corners of base and curb flashing manufactured from non-reinforced GAF TPO designed for advanced protection against heat aging and UV degradation.
EverGuard® Polymat Separation Layer	3 oz./yd.2 polyester mat	Proprietary	A non-woven polyester mat for use as a slip sheet below mechanically secured single ply roof membranes.
EverGuard® Polymat Cushioning Layer	6 oz./yd.2 polyester mat	Proprietary	A non-woven polyester mat for use as a slip sheet below mechanically secured single ply roof membranes.
TPO Red Primer	1 Gallon	Proprietary	Tinted primer used on TPO to improve adhesion of Topcoat® coatings.



<b>Product</b>	<b>Dimensions</b>	<b>Test Specification</b>	<b>Product Description</b>
FlexSeal™ Sealant	1 or 5 gallons or 1 qt. tube	TAS 139	Solvent-based elastomeric sealant.
VersaShield® Fire-Resistant Roof Deck Protection	12" x 100' rolls	ASTM D226	Non-asphaltic fiberglass reinforced underlayment and /or fire barrier.
VersaShield® Solo™ Fire-Resistant Slip Sheet	42" roll wide, 100 ft.	ASTM D146, D828, D4869, D6757	Non-asphaltic, fire resistant fiberglass underlayment.

**APPROVED INSULATIONS:**

**TABLE 2  
Product Description**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
EnergyGuard™ Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ NH Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Cover Board	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ NH HD Cover Board	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ HD Plus Cover Board	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ NH HD Plus Cover Board	High density polyisocyanurate foam insulation	GAF
EnergyGuard™ Ultra Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ NH Ultra Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ Ultra Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF
EnergyGuard™ RA Tapered Polyiso Insulation	Polyisocyanurate foam insulation	GAF
Securock® Gypsum-Fiber Roof Board	Gypsum board	United States Gypsum Corp.
Securock® Glass-Mat Roof Board	Gypsum board	United States Gypsum Corp.
DensDeck® Roof Board	Gypsum board	Georgia-Pacific Gypsum LLC
DensDeck® Prime Roof Board	Gypsum board	Georgia-Pacific Gypsum LLC
Structodek® High Density Fiberboard Roof Insulation	High-density fiberboard	Blue Ridge FiberBoard, Inc.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Drill-Tec™ #12 Fastener	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating. Available with a pinch point or drill point.	#12 x 8" Max. Length, #3 Phillips Head	GAF
2.	Drill-Tec™ #14 Fastener	Truss head, self-drilling, pinch point, high thread fastener for use in steel, wood or concrete decks.	#14 x 16" Max. Length, #3 Phillips Head.	GAF
3.	Drill-Tec™ XHD Fastener	Truss head, self-drilling, pinch point, high thread fastener for us in wood or steel decks.	#15 x 16" Max. Length, #3 Phillips Head	GAF
4.	Drill-Tec™ 2-3/8 in. Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec™ fasteners.	2-3/8" Round	GAF
5.	Drill-Tec™ 2 in. Double Barbed XHD Plate	Round galvanized steel stress plates for use with Drill-Tec™ fasteners.	2" Round	GAF
6.	Drill-Tec™ 2-3/4 in. Barbed SXHD Plate	Round galvanized steel stress plates for use with Drill-Tec™ fasteners.	2-3/4" Round	GAF
7.	Drill-Tec™ SXHD Fastener	Truss head, self-drilling, drill point, high thread fastener for use in steel decks.	#21 x 16" Max. Length, #3 Phillips Head	GAF
8.	Drill-Tec™ AccuTrac® Flat Plate	A2-SS aluminized steel plate for use with Drill-Tec™ fasteners.	3" Square; .017" Thick	GAF
9.	Drill-Tec™ AccuTrac® Recessed Plate	Galvalume® steel plate with recess for use with Drill-Tec™ fasteners.	3" Square; .017" Thick	GAF
10.	Drill-Tec™ ASAP 3S	Drill-Tec™ #12 Fastener with Drill-Tec™ 3" Standard Steel Plate.	See Components	GAF
11.	Drill-Tec™ RhinoBond® TPO SXHD Plate	Gold primer coated plate for use with TPO membranes.	3" Round	GAF





**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
12.	Drill-Tec™ RhinoBond® TPO XHD Plates	Gold primer coated plate for use with TPO membranes.	3" Round	GAF
13.	Drill-Tec™ 3" Steel Plates	Round Galvalume® steel stress plate with reinforcing ribs and recessed for use with Drill-Tec™ fasteners.	3" Round	GAF
14.	Drill-Tec™ 3" Standard Steel Plate	Galvalume® coated steel stress plate for use with approved Drill-Tec™ fasteners.	3" Round	GAF
15.	Drill-Tec™ Eyehook AccuSeam Plates	Round Galvalume® steel plate for use with Drill-Tec™ fasteners.	2-3/8" Round	GAF
16.	Drill-Tec™ 3 in. Ribbed Galvalume Plate (Flat)	Round Galvalume® plated steel stress plate with reinforcing ribs for use with Drill-Tec™ fasteners.	3" Round	GAF
17.	Drill-Tec™ Purlin Fastener	Hex head, 3/4 in. drill point fastener used to attach single-ply to structural steel purlins.	4" - 10" Max. Length, With #3 Square Head	GAF
18.	Drill-Tec™ Base Sheet Fastener (1.7 in.)	G-90 galvanized fastener with plate for base sheet attachment to gypsum decks and lightweight insulating concrete decks. Coated with CR-10 fluorocarbon coating.	1.125" head x 1.75" length. 2.75" Galvalume steel stress plate.	GAF
19.	Drill-Tec™ Base Sheet Fastener E (1.7 in)	G-90 galvanized fastener with plate for base sheet attachment to gypsum decks and lightweight insulating concrete decks. Coated with CR-10 fluorocarbon coating.	1.125" head x 1.75" Length. 2.75" Galvalume steel stress plate.	GAF
20.	Drill-Tec™ Locking Impact Nail	Preassembled fastener/plate unit for base ply and insulation attachment to cementitious wood fiber, poured gypsum and lightweight insulating concrete decks.	Various	GAF



**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Name</u>	<u>Report Identifier</u>	<u>Date</u>	
FM Approvals	4470	3003617	12/20/99	
	4470	3015578	05/12/04	
	4470	3038318	12/10/10	
	4470	3041535	06/08/11	
	4470	3047636	08/08/13	
	4470	3058483	12/09/16	
	4470	3060615	01/23/17	
	4470	FM Letter	09/02/10	
	4470	FM Letter	05/21/13	
	4470	797-07744-267	10/17/12	
	4470	RR209927	05/25/17	
	4470	RR210305	07/05/17	
	UL LLC	UL 790	R10689	06/21/24
		UL 790	R1306	06/27/24
Physical Properties		09CA55838	12/04/10	
Atlantic & Caribbean Roof Consulting, LLC	TAS 114-D	11-067	11/21/11	
	TAS 114-J	15-028	12/01/15	
	TAS 114-J	16-002	03/04/16	
PRI Construction Materials Technologies, LLC	ASTM D6083	GAF-245-02-01	06/10/10	
	ASTM D6083	GAF-276-02-0-R1	01/03/11	
	ASTM C1289	GAF-369-02-01	10/22/12	
	ASTM C1289	GAF-411-20-01	04/30/13	
	ASTM C1289	GAF-412-02-01	04/30/13	
	ASTM C1289	GAF-417-02-01	05/27/13	
	ASTM D6878	GAF 421-02-01	10/22/13	
	ASTM D6878	GAF 422-02-01	10/29/13	
	ASTM D6878	GAF 424-02-01	11/11/13	
	ASTM D6878	GAF 425-02-01	11/11/13	
	TAS 114-H	GAF 457-02-02	01/20/14	
	TAS 114-D	GAF 457-02-08	01/24/14	
	TAS 114-D	GAF 457-02-07	01/24/14	
	TAS 114-J	GAF 457-02-04	01/24/14	
	TAS 114-D	GAF 457-02-06	01/24/14	
	ASTM C1289	GAF-464-02-01	02/05/14	
	ASTM D6083	GAF 499-02-01	03/12/14	
	Physical Properties	GAF-508-02-01	03/12/14	
	TAS 114-J	GAF-538-02-03	08/12/14	
	ASTM D6878	GAF-584-02-01	12/07/15	
	ASTM D6878	GAF-585-02-01	12/07/15	
	ASTM D6878	GAF-586-02-01	12/07/15	
	TAS 139	GAF-671-02-01	06/30/16	
	ASTM C1289	GAF-629-02-01	02/29/16	
	ASTM D6878	GAF-700-02-01	3/10/17	
	ASTM C1289	GAF-704-02-01	09/22/16	
	ASTM C1289	GAF-706-02-01	09/22/16	
ASTM C1289	GAF-707-02-01	09/22/16		



<u>Test Agency</u>	<u>Test Name</u>	<u>Report Identifier</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	ASTM C1289	GAF-714-02-01	11/09/16
	ASTM C1289	GAF-760-02-01	05/15/17
	ASTM C1289	GAF-769-02-01	03/21/18
	ASTM C1289	GAF-772-02-01	08/01/17
	ASTM C1289	GAF-774-02-01	08/01/17
	ASTM C1289	GAF-786-02-01	10/30/17
	ASTM C1289	GAF-856-02-01	1/23/19
	ASTM C1289	GAF-857-02-01	9/20/18
	ASTM D6878	GAF-870-02-01	02/15/19
	Proprietary	376T0003	07/23/19
	Proprietary	376T0004	07/23/19
	Proprietary	376T0051-1	01/27/20
	ASTM D6878	376T0114	09/13/21
	Proprietary	376T0465	10/24/23
	ASTM D6878	376T0390	11/13/23
	ASTM D6878	376T0391	11/13/23
	Proprietary	376T0466	01/05/24
	Proprietary	376T0496.2	02/15/24
	ASTM D6878	376T0456	06/06/24
	ASTM D6878	376T0457	06/06/24
	Trinity   ERD	ASTM D6164	G31360.03.10
ASTM D6163		G34140.04.11-2-R1	04/25/11
ASTM D4601		G34140.04.11-4-R2	04/25/11
ASTM D4897		G34140.04.11-5-R3	10/18/13
ASTM D6163		G40630.01.14-1	01/06/14
ASTM D6164		G40630.01.14-2A	01/07/14
ASTM D1897 / TAS 105		GAF-SC8580.01.16-6	01/20/16
TAS 114-J		GAF-SC8580.03.16-5-R2	08/29/16
TAS 114-D / TAS 114-J		GAF-SC8580.11.15-2	11/18/15
TAS 114-J		GAF-SC8580.11.15-4	11/09/15
TAS 114		GAF-SC8580.11.15-3	11/09/15
ASTM D6164	GAF-SC13105.03.17-R1	03/23/17	
NEMO   etc.	ASTM D6163	4q-GAF-19-SSMBB-02.A	04/08/19
	ASTM D2178	4S-GAF-18-001.01.19-1	01/02/19



## DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Robert Nieminen, P.E.	GAF-SC8580.11.15-4	E(1)	11/09/15
Randall Fowler, P.E.	ACRC 15-028	E(2)	02/17/16
Randall Fowler, P.E.	ACRC 16-002	E(3)	03/15/16
Robert Nieminen, P.E.	GAF-SC8580.03.16-5-R2	E(4), E(5)	08/29/16
Duc T. Nguyen, P.E.	GAF-457-02-04	F(1)	10/27/16
Robert Nieminen, P.E.	GAF-SC8580.11.15-2	F(7)	11/18/15
Duc T. Nguyen, P.E.	GAF-538-02-03	F(8)	10/27/16



**APPROVED ASSEMBLIES:**

**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type E(1):** Membrane mechanically attached through LWC to structural deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the structural deck per manufacturer’s instructions. Structural deck should record a Minimum Characteristic Resistance Force (MCRF) of 525 lbf. when tested with Drill-Tec™ XHD Fasteners through the LWC into the steel deck or Drill-Tec™ #14 Fasteners through the LWC into the structural concrete deck in accordance with TAS 105. Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fastener (1.7 in.) or Drill-Tec™ Base Sheet Fastener E (1.7 in.) fastened into the LWC in accordance with TAS 105.

**Deck:** 22 ga. type BV, G-90 steel meeting ASTM A653, Grade 33 at 72” spans, attached with 5/8” puddle welds spaced 6” o.c. Side laps are attached with #12-24 x 7/8” HWH spaced 18” o.c.  
Or  
Structural Concrete.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Slip Sheet:** VersaShield® Fire-Resistant Roof Deck Protection, VersaShield® Solo™ Fire-Resistant Slip Sheet, GAFGLAS® #75 Base Sheet or EverGuard® Polymat Separation Layer installed in accordance with manufacturer’s installation instructions.

**Membrane:** EverGuard® TPO or EverGuard® Extreme® TPO is secured with Drill-Tec™ RhinoBond® TPO XHD Plates or Drill-Tec™ RhinoBond® TPO SXHD Plates and Drill-Tec™ XHD fasteners or Drill-Tec™ #14 Fasteners (to be used when fastening into structural concrete only). Stress plates and fasteners are placed on a 24” x 30” grid and fasteners are driven through the lightweight concrete and into the structural deck. The roof cover is bonded to stress plates using the RhinoBond® Portable Bonding Tool per manufacturer’s installation instructions. Weighted cooling magnets are placed over the bonded membrane/plates for a minimum of 45 seconds. Side laps are minimum 3” wide and sealed with minimum 1.5” wide heat welds for automatic machine welding. Weld width shall be minimum 2” for hand welding.

**Maximum Design Pressure:** -52.5 psf. (See General limitation #7)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type E(2):** Anchor sheet mechanically attached membrane subsequently adhered.

**Deck Description:** Minimum 231 psi Generic Lightweight Concrete cast over steel deck.  
\*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 70.46 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) or Drill-Tec™ Locking Impact Nails in accordance with TAS 105.

**Deck:** Min. 22 ga., Grade 33, Type BV, G-90 steel decking over ¼” thick steel supports spaced max. 6 ft. o.c. attached 6” o.c. using min. 5/8” diameter puddle welds. Deck side laps are attached 18” o.c. using #12 SD screws.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Anchor Sheet:** GAFGLAS® #75 Base Sheet, GAFGLAS® #80 Ultima™ Base Sheet, GAFGLAS® Stratavent® Nailable Venting Base Sheet or Ruberoid® 20 Smooth mechanically fastened to the lightweight concrete with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) or Drill-Tec™ Locking Impact Nails fastened 7” o.c. in the 4” wide side laps and 7” o.c. in two staggered rows in the field of the sheet.

**Base Ply (optional):** Ruberoid® HW Smooth or Ruberoid® HW 25 Smooth, torch applied.  
Or  
Ruberoid® 20 Smooth, Ruberoid® Mop Smooth 1.5, GAFGLAS® Ply 4 or GAFGLAS® FlexPly 6 adhered in hot asphalt at 20-25 lbs./sq.

**Membrane:** EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered in hot asphalt at 20-25 lbs./sq., or adhered with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5” wide heat weld for automatic machine welding. Weld width shall be a minimum 2” width for hand welding.

**Maximum Design**

**Pressure:** -60 psf. (See General Limitation #7)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type E(3):** Anchor sheet mechanically attached membrane subsequently adhered.

**Deck Description:** Minimum 205 psi Generic Lightweight Concrete cast over steel deck.  
\*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 77.93 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) or Drill-Tec™ Locking Impact Nails in accordance with TAS 105.

**Steel Deck:** Min. 22 ga., Grade 33, Type BV, G-90 steel decking over ¼” thick steel supports spaced max. 6 ft. o.c. attached 6” o.c. using min. 5/8” diameter puddle welds.  
Deck side laps are attached 18” o.c. using #12 SD screws.  
**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Anchor Sheet:** Ruberoid® 20 Smooth mechanically fastened to the lightweight concrete with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) or Drill-Tec™ Locking Impact Nails fastened 7” o.c. in the 4” wide side laps and 7” o.c. in two staggered rows in the field of the sheet.  
Or  
GAFGLAS® #80 Ultima or GAFGLAS® Stratavent® Nailable Base Sheet mechanically fastened to the lightweight concrete with Drill-Tec™ Base Sheet Fasteners (1.7 in.) or Drill-Tec™ Locking Impact Nails fastened 7” o.c. in the 4” wide side laps and 7” o.c. in two staggered rows in the field of the sheet.  
Or  
GAFGLAS® #75 Base Sheet mechanically fastened to the lightweight concrete with Drill-Tec™ Locking Impact Nails fastened 7” o.c. in the 4” wide side laps and 7” o.c. in two staggered rows in the field of the sheet.

**Base Ply:** Ruberoid® HW Smooth or Ruberoid® HW 25 Smooth, torch applied.  
Or  
Ruberoid® 20 Smooth adhered in hot asphalt at 20-25 lbs./sq. (Only for use with GAFGLAS® #75 Base Sheet or GAFGLAS® Stratavent® Nailable Base Sheet anchor sheets).  
Or  
GAFGLAS® Ply 4 or GAFGLAS® FlexPly 6 adhered in hot asphalt at 20-25 lbs./sq. (Only for use with Ruberoid® 20 Smooth anchor sheet).

**Membrane:** EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered in hot asphalt at 20-25 lbs./sq., or adhered with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5” wide heat weld for automatic machine welding. Weld width shall be a minimum 2” width for hand welding.

**Maximum Design Pressure:** -82.5 psf. (See General Limitation #7)



NOA No.: 24-0322.09  
Expiration Date: 04/16/29  
Approval Date: 07/25/24  
Page 15 of 29

**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type E(4):** Membrane is mechanically fastened through LWC to the structural deck.

**Deck Description:** A minimum 2” thick pour of Generic Lightweight Concrete, minimum 210 psi, is poured over the structural deck per manufacturer’s instructions.\* Structural deck should record a Minimum Characteristic Resistance Force (MCRF) of 405 lbf. when tested with Drill-Tec™ XHD Fasteners through the LWC into the steel deck or Drill-Tec™ #14 Fasteners through the LWC into the structural concrete deck in accordance with TAS 105.

\*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fastener (1.7 in.) or Drill-Tec™ Base Sheet Fastener E (1.7 in.) in the LWC in accordance with TAS 105.

**Deck:** Minimum 22 ga. type BV, G-90 steel meeting ASTM A653 with minimum Grade 33 yield strength at 72” spans, attached with 5/8” puddle welds spaced 6” o.c. Side laps are attached with #12-24 x 7/8” HWH spaced 18” o.c.

Or

Structural Concrete.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** EverGuard® TPO, EverGuard Extreme® TPO, EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back is mechanically attached with Drill-Tec™ XHD Fasteners or Drill-Tec™ #14 Fasteners (to be used when fastening into structural concrete only) and Drill-Tec™ 2 in Double Barbed XHD Plates, Drill-Tec™ 2 3/8 in. Barbed XHD Plates or Drill-Tec™ Eyehook AccuSeam Plates spaced 12” o.c. within 6” wide side laps with rows spaced 54” o.c.; sealed with a 1.5 in. wide heat weld.

**Maximum Design**

**Pressure:** -45 psf. (See General Limitation #7)





**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type E(5):** Membrane is mechanically fastened through LWC to the structural deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the steel deck per manufacturer's instructions.\* Structural deck should record a Minimum Characteristic Resistance Force (MCRF) of 608 lbf. when tested with Drill-Tec™ XHD Fasteners through the LWC into the steel or Drill-Tec™ #14 Fasteners through the LWC into the structural concrete in accordance with TAS 105. \*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.) or Drill-Tec™ Base Sheet Fasteners E (1.7 in.) in accordance with TAS 105.

**Deck:** Minimum 22 ga. type BV, G-90 steel meeting ASTM A653 with minimum Grade 49 yield strength at 72" spans, attached with 5/8" puddle welds spaced 6" o.c. Side laps are attached with #12-24 x 7/8" HWH spaced 18" o.c.

Or

Structural Concrete

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** EverGuard® TPO, EverGuard Extreme® TPO, EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back is mechanically attached with Drill-Tec™ XHD Fasteners or Drill-Tec™ #14 Fasteners (to be used when fastening into structural concrete only) and Drill-Tec™ 2 3/4 in. Barbed SXHD Plates spaced 12" o.c. within 6" wide side laps with rows spaced 54" o.c.; sealed with a 1.5 in. wide heat weld.

**Maximum Design**

**Pressure:** -67.5 psf. (See General Limitation #7)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(1):** Membrane adhered to roof deck.

**Deck Description:** Mearlcrete Cellular Lightweight Insulated Concrete over Steel

**Lightweight Concrete:** The deck is filled with a slurry coat of Mearlcrete Cellular Lightweight Concrete, minimum 297 psi, to a depth of 1/8" above the top deck rib. EPS Holey Board with 3" diameter holes is placed into the slurry, followed by a minimum 2" thick pour of Mearlcrete Cellular Lightweight concrete, minimum 297 psi.

**Steel Deck:** Minimum 22 ga. Grade 33, Type BV, G-90, at 6' span, 5/8" puddle welds at 6" o.c. along structural supports. Deck side laps secured at 18" o.c. with #12-14 x 7/8 HWH.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design**

**Pressure:** -52.5 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(2):** Membrane adhered to roof deck.

**Deck Description:** Mearlcrete Cellular Lightweight Concrete over Structural Concrete

**Lightweight Concrete:** The deck is filled with a slurry coat of Mearlcrete Cellular Lightweight Concrete, minimum 297 psi, to a depth of 1/8" above the top deck rib. EPS Holey Board with 3" diameter holes is placed into the slurry, followed by a minimum 2" thick pour of Mearlcrete Cellular Lightweight concrete, minimum 297 psi.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using or adhered with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.  
Or  
One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.  
Or  
One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design Pressure:** -205 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(3):** Membrane adhered to roof deck.

**Deck Description:** Elastizell Cellular Lightweight Concrete over Structural Concrete.

**Lightweight Concrete:** A 1/8" thick slurry of Elastizell Cellular Lightweight Concrete, minimum 222 psi, is poured over structural concrete deck. EPS Holey Board with 3" diameter holes is placed into the slurry, followed by a minimum 2" thick pour of Elastizell Cellular Lightweight Concrete, minimum 222 psi.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design Pressure:** -200 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(4):** Membrane adhered to roof deck.

**Deck Description:** Elastizell Lightweight Concrete over Structural Concrete.

**Lightweight Concrete:** A 1/8" thick slurry of Elastizell Cellular Lightweight Concrete, minimum 300 psi, is poured over structural concrete deck. **(Optional)** EPS Holey Board with 3" diameter holes is placed into the slurry, followed by a minimum 2" thick pour of Elastizell Cellular Lightweight Concrete, minimum 300 psi.

**Concrete Deck:** Minimum 3000 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied to the substrate in 3/4" wide ribbons spaced 6" o.c. or adhered with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.  
Or  
One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. in accordance with manufacturer's instructions. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design Pressure:** -75 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(5):** Membrane adhered to roof deck.

**Deck Description:** Concrecel Cellular Lightweight Concrete over Structural Concrete.

**Lightweight Concrete:** A 1/8" thick slurry of Concrecel Cellular Lightweight Concrete, minimum 200 psi, is poured over structural concrete deck. EPS Holey Board with 3" diameter holes is placed into the slurry, followed by a minimum 2" thick pour of Concrecel Cellular Lightweight Concrete, minimum 200 psi.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. in accordance with manufacturer's instructions. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design Pressure:** -225 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(6):** Membrane adhered to roof deck.

**Deck Description:** Celcore Cellular Lightweight Concrete over Structural Concrete.

**Lightweight Concrete:** Celcore Cellular Lightweight Concrete, minimum 200 psi, is poured over structural concrete deck per manufacturer's instructions.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O or LRF Adhesive M applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design**

**Pressure:** -300 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(7):** Membrane adhered to roof deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the steel deck per manufacturer's instructions.

\*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 70.46 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) in accordance with TAS 105.

**Steel Deck:** 22 ga. type BV, G-90 steel meeting ASTM A653, Grade 33 at 72" spans, attached with 5/8" puddle welds spaced 6-inch o.c. Side laps are attached with #12-24 x 7/8" HWH spaced 18" o.c.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design**

**Pressure:** -52.5 psf. (See General Limitation #9)





**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(8):** Membrane adhered to roof deck.

**Deck Description:** A minimum 2” thick pour of Elastizell Lightweight Concrete, minimum 200 psi, is poured over the steel deck per manufacturer’s instructions with minimum 1” EPS Holey Board. Minimum 2” slurry coat poured over the EPS.

**Steel Deck:** 22 ga. type BV, G-90 steel meeting ASTM A653, Grade 33 at 72” spans, attached with 5/8” puddle welds spaced 6-inch o.c. Side laps are attached with #12-24 x 7/8” HWH spaced 18” o.c.

**This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.**

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5” wide heat weld for automatic machine welding. Weld width shall be a minimum 2” width for hand welding.

**Maximum Design**

**Pressure:** -60 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(9):** Membrane adhered to roof deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the structural concrete deck per manufacturer's instructions. \*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) in accordance with TAS 105.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O applied in 0.75" ribbons 4" o.c. for full coverage. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

Or

One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using EverGuard® WB181 Bonding Adhesive applied at 120 ft<sup>2</sup>/gal. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design**

**Pressure:** -75 psf. (See General Limitation #9)



**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(10):** Membrane adhered to roof deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the structural concrete deck per manufacturer's instructions. \*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) in accordance with TAS 105.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive M applied in 0.75" ribbons 6" o.c. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design**

**Pressure:** -67.5 psf. (See General Limitation #9)



NOA No.: 24-0322.09  
Expiration Date: 04/16/29  
Approval Date: 07/25/24  
Page 27 of 29

**Membrane Type:** TPO

**Deck Type 4:** Lightweight Insulating Concrete, Non-Insulated

**System Type F(11):** Membrane adhered to roof deck.

**Deck Description:** Generic Lightweight Concrete, minimum 180 psi, is poured over the structural concrete deck per manufacturer's instructions. \*Lightweight concrete should record a Minimum Characteristic Resistance Force (MCRF) of 97 lbf. when tested with Drill-Tec™ Base Sheet Fasteners (1.7 in.), Drill-Tec™ Base Sheet Fasteners E (1.7 in.) in accordance with TAS 105.

**Concrete Deck:** Minimum 2500 psi structural concrete.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** One ply of EverGuard® TPO Fleece-Back or EverGuard Extreme® TPO Fleece-Back adhered to lightweight insulating concrete using LRF Adhesive O applied in 0.75" ribbons 6" o.c. or adhered with OlyBond 500® applied in a spatter pattern at 0.318 gal./sq. The side laps are sealed with a 1.5" wide heat weld for automatic machine welding. Weld width shall be a minimum 2" width for hand welding.

**Maximum Design Pressure:** -75 psf. (See General Limitation #9)



## LIGHTWEIGHT INSULATING CONCRETE SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.
3. For Systems where specific lightweight insulating concrete is referenced consult current lightweight insulating concrete NOA for specific deck construction and limitations. For systems where specific lightweight insulating concrete is not referenced, the minimum design mix shall be a minimum of 300 psi.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 24-0322.09  
Expiration Date: 04/16/29  
Approval Date: 07/25/24  
Page 29 of 29