



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

Mid-States Asphalt and Cant Strip, Inc.
1637 51st Avenue
Tuscaloosa, AL. 35401

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: MSA Quik-Felt and MSA Quik Felt Deck Guard Underlayments

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge Acebo.

07/11/24



NOA No.: 24-0402.05
Expiration Date: 07/11/29
Approval Date: 07/11/24
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **Quik-Felt and Quik Felt Deck Guard Underlayments** as described in this Notice of Acceptance; for use with approved prepared roof assemblies where ASTM D8257 underlayment is specified, designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code. (See Limitations Below.)

PRODUCT DESCRIPTION

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Quik-Felt	Width = 48" Length = 250'	ASTM D8257	A polymeric, mechanically attached, underlayment for use in steep slope roofing.
Quik Felt Deck Guard	Width = 48" Length = 250'	ASTM D8257	A polymeric, mechanically attached, underlayment for use in steep slope roofing.

EVIDENCE SUBMITTED

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies, Inc.	1085T0040	ASTM D8257	01/05/23
	1085T0045	ASTM D8257	08/08/23

MANUFACTURING LOCATION:

1. Santej, India

INSTALLATION:

1. **Quik-Felt and Quik Felt Deck Guard** shall be installed in strict compliance with applicable Building Code requirements with prescribed approved fasteners and fastener densities.
2. **Quik-Felt and Quik Felt Deck Guard** shall be installed with a minimum 4-inch head lap in a shingle layer fashion and a 12" end lap where required as specified by manufacturer's specifications.
3. **Quik-Felt and Quik Felt Deck Guard** shall be fastened with corrosion resistant tin-caps and 12 gauge 1¼" annular ring-shank nails, spaced 6" o.c. at all laps and staggered rows fastened 12" o.c. in the field of the roll at a row spacing of 12 inches on center. For the 48-inch wide roll a minimum of four rows of fasteners spaced as previously specified is required.
4. **Quik-Felt and Quik Felt Deck Guard** may be used with asphaltic shingles, wood shakes and shingles, non-structural metal roofing, and quarry slate.



NOA No.: 24-0402.05
Expiration Date: 07/11/29
Approval Date: 07/11/24
Page 2 of 3

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. **Quik-Felt and Quik Felt Deck Guard** are components used in roof assemblies. Roof assemblies are approved under specific roof system Notice of Acceptance.
3. **Quik-Felt and Quik Felt Deck Guard** shall be applied in strict compliance with applicable building code to a smooth, clean and dry surface. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code and be free of irregularities.
4. **Quik-Felt and Quik Felt Deck Guard** shall not be used in roof tile assemblies, nor shall it be hot mopped or be applied over a pre-existing roof membrane as a recover system, refer to manufacturer's published literature for product compatibility.
5. **Quik-Felt** shall not be left exposed as a temporary roof for longer than 90 days of application. **Quik Felt Deck Guard** shall not be left exposed as a temporary roof for longer than 60 days of application.
6. **Quik-Felt and Quik Felt Deck Guard** may be used with any approved roof covering Notice of Acceptance listing **Quik-Felt and Quik Felt Deck Guard Synthetic Underlayments** as a component part of an assembly in the Notice of Acceptance. If **Quik-Felt and Quik Felt Deck Guard Synthetic Underlayments** are not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 24-0402.05
Expiration Date: 07/11/29
Approval Date: 07/11/24
Page 3 of 3