

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Blac Investments, Inc. dba Tri County Metals 4949 SW State Road 26 Trenton, FL. 32693

#### SCOPE:

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas, where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

#### **DESCRIPTION: 1.5 MS Lok 24 Guage Metal Panels over Wood Deck**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5. The submitted documentation was reviewed by Alex Tigera.

NOA-No.: 24-1022.04 Expiration Date: 12/19/29 Approval Date: 12/19/24 Page 1 of 5

12/19/24

# **ROOFING SYSTEM APPROVAL:**

<u>Category:</u>	Roofing
Sub-Category:	Metal, Panels (Non-Structural)
<u>Material:</u>	Steel
Deck Type:	Wood
Maximum Design Pressure	-176 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<b>Product</b>	<b>Dimensions</b>	Test <u>Specifications</u>	Product <u>Description</u>
1.5 MS Lok 24 Guage Metal Panel	Length: various Height: 1-1/2" Width: 16" Min. Thickness 24 ga Min. Yield Strength: 56.1 ksi.	TAS 110	Corrosion resistant, galvalume, preformed, standing seam panel coated with coatings of Fluropon <sup>®</sup> .
1.5 ML Clip	Length: 4.5" Height: 1.5" Min. Thickness 22 ga. Base: 16 ga.	TAS 110	Corrosion resistant, Min. 22 ga. steel clip With 16ga. base.

#### **MANUFACTURING LOCATION**

1. Trenton, FL.

### **EVIDENCE SUBMITTED:**

<b>Test Agency</b>	Test Agency	Test Agency	<b>Test Agency</b>
PRI Asphalt Technologies, Inc.	1930T0037	TAS 125	07/25/22
	1930T0026	TAS 125	12/03/21
	1930T0024	TAS 100	12/09/21
	1930T0011	ASTM G 155	02/09/21
	1930T0010	ASTM B 117	01/14/20



### **APPROVED ASSEMBLIES:**

System:	1.5 MS Lok 24 Guage Metal Panel
Deck Type:	Wood, Non-insulated
Deck Description:	New Construction $^{19}/_{32}$ " or greater plywood or wood plank, or for re-roofing $^{15}/_{32}$ " or greater plywood.
Slope Range:	2": 12" or greater
Maximum Uplift Pressure:	See Table A below
Deck Attachment:	In accordance with applicable Building Code, but in no case shall it be less than 8d annular ring shank nails spaced at a distance listed below in <b>Table A</b> . In reroofing, where the deck is less than $19/32$ " thick (Minimum $15/32$ ") The above attachment method must be in addition to existing attachment.
Underlayment:	Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4" side- lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-caps and 12 gauge 1 <sup>1</sup> / <sub>4</sub> " annular ring-shank nails, spaced 6" o.c. at all laps and two staggered rows 12" o.c. in the field of the roll or any approved underlayment having a current NOA.
Fire Barrier:	Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.
Valleys:	Valley construction shall be in compliance with Roofing Application Standard RAS 133 and with Blac Investments, Inc. dba Tri County Metals current published installation instructions.
Metal Panels and Accessories:	Install the "1.5 MS Lok 24 Guage Metal Panel" including flashing penetrations, valleys, end laps and accessories in compliance with Blac Investments, Inc. dba Tri County Metal's current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.
	Panels shall be secured along the male rib with 1.5 ML Clip using two (2) corrosion resistant #10 x 1 $\frac{1}{2}$ " pancake head screws of sufficient length to penetrate through the sheathing a minimum of $\frac{3}{16}$ ". The panel clips were placed at a spacing listed in Table A below. The female rib of panel is installed over the male rib of panel. Panels are seamed as listed below in <b>Table A</b> .

	TABLE A Maximum Design Pressures	
Roof Areas	Field	Perimeter and Corner <sup>1</sup>
Maximum Design Pressures	-142.5 psf	–176 psf
Maximum Clip Spacing	16" o.c.	6" o.c.
Panel Seam	180° degrees	180° degrees
Plywood Deck Attachment Spacing	6" o.c.	4" o.c.
1. Extrapolation shall not be allowed		



NOA-No.: 24-1022.04 Expiration Date: 12/19/29 Approval Date: 12/19/24 Page 3 of 5

### LIMITATIONS


- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e., field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e., perimeters, extended corners and corners).
- **3.** Panels may be rolls formed in continuous lengths from eave to ridge. Maximum lengths shall be as described in Roofing Application Standard RAS 133.
- 4. All panels shall be permanently labeled with the manufacturer's name and/or logo, city, state, and the following statement: "Miami-Dade County Product Control Approved" **or** with the Miami-Dade County Product Control Seal as seen below. All clips shall be permanently labeled with the manufacturer's name and/or logo, and/or model.



5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.



## **PROFILE DRAWINGS**



1.5" ML Clip

# END OF THIS ACCEPTANCE



NOA-No.: 24-1022.04 Expiration Date: 12/19/29 Approval Date: 12/19/24 Page 5 of 5